IEC IECEE CB SCHEME	Ref. Certif. No.
	CN49792

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Auxiliary Contacts
Name and address of the applicant	Schneider Electric Industries SAS 35 Rue Joseph Monier 92500 Rueil-Malmaison, France
Name and address of the manufacturer	Schneider Electric Industries SAS 31 rue Pierre Mendès-France 38320 EYBENS, France
Name and address of the factory Note: *When more than one factory, please report on page 2*	InnoVista Sensors Industry (Huizhou) Ltd. 3rd and 4th Floor, No.6 Huifeng West 2nd Road, Pingnan Industrial Park, Zhongkai Hi-tech Industrial Development Zone, Huizhou, Guangdong Province, P.R.China
Ratings and principal characteristics	See the Appendix
Trademark (if any)	Schneider electric
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	CE, CD, CT Standard; CE, CD, CT Low Level; EF Standard; EF Low Level
Additional information (if necessary may also be reported on page 2)	
A sample of the product was tested and found to be in conformity with	IEC 60947-5-1:2016(4th Edition)
As shown in the Test Report Ref. No. which forms part of this Certificate	00901-CB2016CQC-071862

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE
Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: http://www.cqc.com.cn

Date: Mar.25,2020

Signature: Lu Mei

CB 0055805

CE, CD, CT Standard; CE, CD, CT Low Level; EF Standard; EF Low Level
Uimp:8kV;
Ui:690V(CE,CD,CT,EF Standard),380V(CE,CD,CT, EF Low Level);
Ith:8A(CE,CD,CT,EF Standard),5A(CE,CD,CT, EF Low Level);
CE,CD,CT Standard:
AC-12: AC240V/380V/8A,480V/8A,690V/6A;
DC-12: DC24V/2.5A,48V/2.5A,125V/0.8A,250V/0.3A;
CE,CD,CT Low Level:
AC-12: AC24V/48V/5A,240V/380V/5A;
DC-12:DC24V/2.5A,48V/2.5A,125V/0.8A,250V/0.3A;
EF Standard:
AC-12:AC240V/380V/6A,480V/6A,690V/6A;
DC-12:DC24V/2.5A,48V/2.5A,125V/0.8A,250V/0.3A;
EF Low Level:
AC-12:AC24V/48V/5A,240V/380V/5A;
DC-12:DC24V/2.5A,48V/2.5A,125V/0.8A,250V/0.3A

Additional information (if necessary)

Date: Mar.25,2020

Signature: 陆梅
Lu Mei

CHINA QUALITY CERTIFICATION CENTRE
Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666
Fax: +86-10-83886282
website
http://www.cqc.com.cn