Ref. Certif. No.
CN73621

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	AC Contactor
Name and address of the applicant	Schneider Electric Industries SAS 35 Rue Joseph Monier 92500 Rueil-Malmaison, France
Name and address of the manufacturer	Schneider Electric Industries SAS 35 Rue Joseph Monier 92500 Rueil-Malmaison, France
Name and address of the factory Note: *When more than one factory, please report on page 2*	Schneider Electric a. s. Cizovska 447 - 39701 Pisek - Czech Republic ☑ Additional information on page 2
Ratings and principal characteristics	LC1F2600:Ui: 1000V;Uimp: 8kV;Ith: 2600A;AC-1: Ue/Ie: 1000V/2600A;LC1F2600S410, LC1F2600S411, LC1F2600LS410, LC1F2600LS411: Ui: 1250V;Uimp: 12kV;Ith: 2600A;AC-1: Ue/Ie: 1000V/2600A;Us: AC220V, 230V, 240V, 415V, 440V 40-400Hz; DC220V, DC440V; 100-250V 50/60Hz/DC;Pole: 3P;Frequency: 50/60Hz;
Trademark (if any)	Schneider Electric
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	LC1F2600, LC1F2600S410, LC1F2600S411, LC1F2600LS410, LC1F2600LS411;
Additional information (if necessary may also be reported on page 2)	
A sample of the product was tested and found to be in conformity with	IEC 60947-1:2020;IEC 60947-4-1:2023
As shown in the Test Report Ref. No. which forms part of this Certificate	00901-CB2025CQC-123606

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.
Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: http://www.cqc.com.cn

Date: Sep.29,2025

Signature: 谢肇煦
Xie ZhaoXu

Name of the factory	Address of the factory
Schneider （Shanghai）Apparatus Parts Manufacturing Co., Ltd. Putuo Branch	Block A, Building 2, No.629 Suide Road, Putuo District, Shanghai

Additional information (if necessary)

Date: Sep.29,2025

Signature: 谢肇煦
Xie ZhaoXu