Ref. Certif. No.

FR_722035

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Auxiliary Contact Blocks
Name and address of the applicant	**SCHNEIDER ELECTRIC INDUSTRIES SAS** 35, rue Joseph Monier 92500 RUEIL-MALMAISON - FRANCE
Name and address of the manufacturer	**SCHNEIDER ELECTRIC INDUSTRIES SAS** 35, rue Joseph Monier 92500 RUEIL-MALMAISON - FRANCE
Name and address of the factory	**SCHNEIDER ELECTRIC A.S.** Cizovska 447 - 39701 PISEK - CZECH REPUBLIC
Note: *When more than one factory, please report on page 2*	☐ Additional Information on page 2
Ratings and principal characteristics	See Annex
Trademark / Brand (if any)	Schneider Electric
Customer's Testing Facility (CTF) Stage used	/
Model / Type Ref.	GVAED101, GVAED011, GVAED1013, GVAED0113
Additional information (if necessary may also be reported on page 2)	Supersedes CBTC FR_708751/M1 dated 26/11/2024. Update further to the evolution of the standard(s) ☐ Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60947-1:2020 IEC 60947-5-1:2024
As shown in the Test Report Ref. No. which forms part of this Certificate	25119Y90027

This CB Test Certificate is issued by the National Certification Body

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 15/07/2025

Signature: Julien GAUTHIER
Certification Officer

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES S.A.S au capital de 15.745.984 € RCS Nanterre B 775 685 019 33 Avenue du Général Leclerc 92260 FONTENAY AUX ROSES

ANNEX

References, ratings and main characteristics:

	Mounting on GV3	Number max	Type of contact	Terminals type
GV AED101	Front	1	1 NO + NO fault	Screw lug
GV AED011	Front	1	1 NO + NO fault	Screw lug
GV AED1013	Front	1	1 NO + NO fault	Screwless-type
GV AED0113	Front	1	1 NO + NO fault	Screwless-type

Type of contact elements	X, Y
Number of contacts	1NC+1NO
Conventional free air thermal current Ith (A)	2,5A
Rated insulation voltage Ui (V)	250V
Rated impulse withstand voltage Uimp (kV)	4kV
Utilization category	AC-15, DC-13
Rated operational voltage Ue (V)	AC24V,48V,100-127V,230-240V; DC24V,48V,60V
Rated frequency (Hz)	50/60Hz for AC
Rated operational current Ie (A)	AC-15: Ie/Ue: 2A/24VAC, 1,25A/48VAC, Ie/Ue: 1,5A/100-127VAC, 0,75A/230-240VAC DC-13: Ie/Ue: 1A/24VDC; 0,3A/48VDC ; 0,15A/60VDC;
Rated conditional short-circuit current (kA)	1kA
Kind of protective device	Fuse gG 4A
IP Code	IP2X
Pollution degree	3

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 15/07/2025

Signature: Julien GAUTHIER
Certification Officer