HOFFMAN ENCLOSURES, INC.
2100 Hoffman Way
Minneapolis, MN 55303-1745, USA
+1.763.421.2240 main

Declaration of Conformity

Issued by Manufacturer
Hoffman Enclosures, Inc.
2100 Hoffman Way, Anoka, Minnesota 55303-1745, U.S.A.
declare at our sole responsibility, that these devices are designed and constructed according to the fundamental safety and health requirements.

Enclosure Models:	**ASB**3R, ASB**4R (Bulletin S90B)**
Equipment Description:	**Hoffman Splitter Box, Type 1**
Enclosure Rating :	**CSA Type 1**
Enclosure Certification:	**CSA C22.2 No. 76-14**

PRODUCTS

CLASS 4662 02 - WIREWAYS AND BUSWAYS - Splitters

Splitter Boxes in a general-purpose, sheet steel (Type 1) enclosure; Cat. Number Series ASBXX3R and ASBXX4R; containing terminal blocks suitable for copper only 3 or 4 wires, 400 Amp max., 600 Vac max.

Applicable Standards:	**CAN/CSA C22.2 No. 76-14**	**– Splitters**
	CAN/CSA C22.2 No. 40-1989(R2014)	**– Cutout, Junction, Pull Boxes**

Authorized by: Glen Kampa 5/22/2020 *(today's date)*

Glen Kampa **Date**

Senior Regulatory Engineer

DOC: CERT-00269-B

Subject to Change Without Notice

Certificate of Compliance

Certificate: 1408854 **Master Contract:** 151630 (042184_C_000)

Project: 70177569 **Date Issued:** 2018-05-01

Issued to: **Hoffman Enclosures Inc.**
2100 Hoffman Way
Anoka, Minnesota 55303-1745
USA
Attention: Glen Kampa

The products listed below are eligible to bear the CSA Mark shown

Issued by: *Frank Gessner*
Frank Gessner

PRODUCTS

CLASS 4662 02 - WIREWAYS AND BUSWAYS - Splitters

Splitter Boxes in a general-purpose, sheet steel (Type 1) enclosure; Cat. Number Series ASBXX3R and ASBXX4R; containing terminal blocks suitable for copper only 3 or 4 wires, 400 Amp max., 600 Vac max.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 76-14	- Splitters
CSA C22.2 No. 40-1989 (R2014)	- Cutout, Junction and Pull Boxes