

INSTALLATION INSTRUCTIONS FOR CATALOG NUMBER SCBC

Replacement Circuit Breaker Cover for HUBBELL SPIDER®II

- To be repaired by qualified personnel only.
- Use Factory Authorized replacement parts only.
- Disconnect from power supply.
- Remove four screws holding Circuit Breaker Cover Assembly in place.
- Remove Circuit Breaker Cover Assembly.
- Remove sealing gasket.
- Clean gasket sealing surface.
- Install new sealing gasket.
- Install replacement Circuit Breaker Cover Assembly with hinge on top.
- Install four mounting screws and torque to 20 lb.-in.
- Verify cover opens and closes without binding.
- Inspect SPIDER®II unit. If any part(s) appear to be missing, broken or show signs of damage, replace part(s) with identical one before returning unit to service.
- Test unit for proper operation before returning to service.

TEST PROCEDURE:

All Models

Connect the SPIDER® II unit to an appropriate power source.

CAUTION:

- 1) Power is immediately available at the 30 Amp outlet when the source is energized, if the respective branch circuit breaker on the side of the SPIDER® II unit is in the "ON" position.
 - 2) Power is immediately available at the 50 amp outlet when the source is energized on all SPIDER® II models.
1. Verify all circuit breakers are in the "on" position.
 2. Push the test button on the individual GFCI module. The unit should trip.
 3. Push the reset button. The indicator light should come on.
 4. Repeat steps 2 & 3 for the remaining five modules.
 5. Models SBSB2 and SBTL2 only, equipped with (1) 30 Ampere GFCI circuit breaker
Push the test button. The unit should trip.
 6. Reset the breaker by pushing handle to the "OFF" position then "ON".

If the unit does not trip when tested, or cannot be reset after conducting the recommended troubleshooting procedure, consult Hubbell Incorporated, Milford, Connecticut.