



IMPORTANT SAFEGUARDS

When using electrical equipment, basic safety precautions should always be followed including the following.

READ AND FOLLOW ALL SAFETY INSTRUCTIONS

- 1. Do not use outdoors.
- 2. Do not mount near gas or electric heaters
- Equipment should be mounted in locations and at heights (MAX: 8ft) where it will not be subject to tampering by unauthorized personnel.
- 4. The use of accessory equipment is not recommended by the manufacturer may cause an unsafe condition.
- 5. Do not use this equipment for other than its intended use.
- Before wiring to power supply, turn off electricity at fuse or circuit breaker.
- 7. Consult local building code for approved wiring and installation.
- 8. Installation and servicing should be performed by qualified personnel.

INSTALLER:

•SEE UNIT LABEL FOR ADDITIONAL MODEL SPECIFICATIONS
•SAVE THESE INSTRUCTIONS FOR USE BY OWNER/OCCUPANT

WARNING – This product contains chemicals known to the State of California to cause cancer, birth defects and/or other reproductive harm. Thoroughly wash hands after installing, handling, cleaning, or otherwise touching this product.

INSTALLATION

Ceiling & End Mounting (FIG. A) & (Fig. B).


- 1. Connect input as shown in wiring diagram below and fasten canopy to J-box bracket.
- 2. Snap housing to canopy.
- 3. If the exit has remote capacity, up to 4 remotes can be connected.
- 4. Secure faceplate to housing and remove the proper arrow as required.





WIRING DIAGRAM

Wiring Diagram for Exit Sign(Example: CER)



Wiring Diagram for Exit with Remote Capacity(Example: CERRC)

