

# WIREMOLD



## 24DWND 24DWNR Downward-Facing Device Activations INSTALLATION INSTRUCTIONS

Installation Instruction No.: 1 007 174 – October 2007

Wiremold/Legrand electrical systems conform to and should be properly grounded in compliance with requirements of the current National Electrical Code or codes administered by local authorities.

All electrical products may present a possible shock or fire hazard if improperly installed or used. Wiremold/Legrand electrical products may bear the mark as UL Listed and/or Classified and should be installed in conformance with current local and/or the National Electrical Code.

***IMPORTANT: Please read all instructions before beginning.***

1. Remove appropriate twistout for application.



2. Place upper edge of bracket under upper lip of raceway.



3. Attach bracket to the wall using #8 (5/16" [7.9mm] head size) flat head fastener or equivalent.



4. Feed wire through twistout and snap on raceway covers.



5. Wire device and mount on bracket.



6. Snap device bracket cover onto raceway. Hook under device first, then snap the top onto the raceway.



7. Secure device bracket cover with screws supplied with bracket.



---

# WIREMOLD



**Wiremold / Legrand**

*U.S. and International:*

60 Woodlawn Street • West Hartford, CT 06110

1-800-621-0049 • FAX 860-232-2062 • Outside U.S.: 860-233-6251

*Canada:*

570 Applewood Crescent • Vaughan, Ontario L4K 4B4

1-800-723-5175 • FAX 905-738-9721

