


Mini-Com Shielded Jack Modules - TG Style Termination

Part Numbers: CJS6X88TG**Y, CJSK6X88TG**, CJSQ6X88TGBL, CJSH6X88TG**Y, CJS688TG**Y, CJSK688TG**, CJSQ688TG**, CJSH688TG**Y, CJS5E88TG**Y, CJSK5E88TG**, CJSH5E88TG**Y


© Panduit Corp. 2015

INSTALLATION INSTRUCTIONS


PN366M




CABLE PREPARATION STEPS




For Technical Support: www.panduit.com/resources/install_maintain.asp

TERMINATION STEPS



REMOVAL STEPS



Notes:

1. For specified performance, follow TIA/EIA 568-C installation guidelines.
2. Shielded jack modules can terminate 22-26 AWG solid or stranded IWC data cable with 0.062" (1.57mm) maximum insulated conductor outside diameter.
3. Shielded jack modules may be re-terminated a minimum of 20 times.
4. For technical and performance information, contact Panduit Technical Support.
5. CJSKG-X Grounding Kit is REQUIRED for all Mini-Com Modular Patch Panels, but is optional for Mini-Com All Metal Shielded Modular Patch Panels.

As with all Communication Components, the following statements apply:

1. Never install communications wiring during a lightning storm.
2. Never install communications wiring in wet locations unless the jack is specifically designed for use in wet locations.
3. Never touch uninsulated communications wiring or terminals unless the communication line has been disconnected at the network interface.
4. Use caution when installing or modifying communication wiring.

For Instructions in Local Languages
and Technical Support:

www.panduit.com/resources/install_maintain.asp

PANDUIT
www.panduit.com

E-mail:
techsupport@panduit.com

Phone:
866-405-6654