

BLACK COVER PART NUMBER	USED WITH H-TAP PART NUMBER	USE WITH C-TAP PART NUMBER	USE WITH ARMORED CABLE GROUNDING KIT PART NUMBER
CVR6-1*	HTCT6X-6X-1**	CTAP4-8-L CTAP4-6-L CTAP4-4-L	
CVR2-1*	HTCT2-2-1**	CTAP2-4-Q CTAP2-2-X CTAP2/0-2-X	
CVR250-1*	HTCT250-2-1** HTCT250-250-1**	CTAP2/0-2/0-X	ACGK
CVR500-1		CTAP4/0-2-X CTAP4/0-2/0-X CTAP4/0-4/0-X	AGCK, ACGKX

*Cable ties are not provided with these Black insulating covers.
UL Flammability rating for Black insulating covers is V-0

** UL Listed (cULus) and CSA certified when used with HTCT6X-6X-1, HTCT2-2-1, HTCT250-2-1, or HTCT250-250-1

1. Installation of one piece hinged cover:

- Place connector into center of one cover half.
- Close cover and engage snap-action latches.
- If provided, install two cagle ties around the cover. Tension cable ties and cut off any excess length.

2. Cover removal:

- Cut off cable ties, if installed.
- Insert screwdriver between locking tab and snap latch loop
- Use screwdriver to lift loop over tab.
- Repeat (b) and (c) for remaining latches.
- Open or remove cover.



**BLACK INSULATING COVERS ARE
UL/CSA WHEN INSTALLED WITH
HTCT H-TAPS CONNECTORS**

For Instructions in Local Languages
and Technical Support:

www.panduit.com/resources/install_maintain.asp

PANDUIT
www.panduit.com

E-mail:
techsupport@panduit.com

Phone:
866-405-6654