CERTIFICATE OF COMPLIANCE

Certificate Number	20150724-E84905
Report Reference	E84905-19960503
Issue Date	2015-JULY-24

Issued to:	SCHNEIDER ELECTRIC USA INC / SQUARE D CO 1010 AIRPARK CENTER DR NASHVILLE TN 37217
This is to certify that representative samples of	CIRCUIT BREAKERS, MOLDED CASE AND CIRCUIT-BREAKER ENCLOSURES Molded case circuit breakers, Catalog number prefix ED, EG, EJ and EK Series 3. The 480Y/277 V product ranges in amperes from 15 A to 125 A and the 600Y/347 V product ranges in amperes from 15 A to 100 A. Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.
Standard(s) for Safety:	UL 489 And C22.2 No. 5-02 Standard For Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures.
Additional Information:	See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/