



Certificate of Compliance

Certificate: 1793277 (LR 32390)

Master Contract: 153555

Project: 2525131

Date Issued: May 15, 2012

Issued to: Schneider Electric USA, Inc.

Square D
3700 6th St SW
Cedar Rapids, IA 52404
USA
Attention: Bill Rezac

The products listed below are eligible to bear the CSA Mark shown



R. Tateishi

Issued by: R. Tateishi, P. Eng.

PRODUCTS

CLASS 4652 04 - SWITCHES - Miscellaneous

Instantaneous trip circuit breakers, Powerpact HJ, HL and HR, 3-pole, 150A max, 600V ac max.

Instantaneous trip circuit breakers, Powerpact JJ, JL and JR, 3-pole, 250A max, 600V ac max.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures