



Certificate of Compliance

Certificate: 1867685 (LR 44087-148)

Master Contract: 225619

Project: 2005985

Date Issued: 2008/03/11

Issued to: Telemecanique/Schneider Electric

Industries SAS

BP 660

Zone Industrielle No. 3

L'Isle d'Espagnac, 16340

France

Attention: Mr. Jean-Pierre Laidet

The products listed below are eligible to bear the CSA Mark shown



Issued by: Jean-Claude Chow, Eng.

Authorized by: Helene Vaillancourt,
Operations Manager

PRODUCTS

CLASS 3211 03 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary
Devices

Control stations, Cat. No. XAL-D or -K followed by 1, 2, 3, 4 or 5, followed by a two digit number, may be followed by a letter and/or a one digit number, followed by H7; and Cat. No. XAL-D or -K followed by 01, 02, 03, 04 or 05, followed by H7. Enclosure Type 4X, 12 and 13.

Ratings:

- The contact blocks are rated A600, R300.



Certificate: 1867685 (LR 44087-148)

Master Contract: 225619

Project: 2005985

Date Issued: 2008/03/11

- The pilot lights LED Type are rated 24 Vac/dc, 48 .. 120 Vac, 230/240 Vac.

Note: These devices are enclosed manually operated control stations for use with CSA certified operating heads Cat. No. ZB5-A, contact blocks Cat. No. ZEN-L and/or pilot lights Cat No. ZAL-V.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 14-05 - Industrial Control Equipment

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures