

# Certificate of Compliance

**Certificate:** 1765916 (LR 89150)

**Master Contract:** 226596

**Project:** 1765916

**Date Issued:** 2006/07/19

**Issued to:** Telemecanique/Schneider  
Automation SAS  
Zone Industrielle Sud  
Rue Lavoisier  
BP 6  
Longvic Les Dijon, 21601  
France  
Attention: Mr. Christian Desante

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:** Patrick Quinty, Eng.

**Authorized by:** Helene Vaillancourt,  
Operations Manager



## **PRODUCTS**

**CLASS 2252 01** - PROCESS CONTROL EQUIPMENT

**CLASS 2258 02** - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

**PART A:**

**CLASS 2252 01** - PROCESS CONTROL EQUIPMENT

Programmable Controllers, Series Twido, open type, DIN rail mounted 60°C.



**Certificate:** 1765916 (LR 89150)

**Master Contract:** 226596

**Project:** 1765916

**Date Issued:** 2006/07/19

---

Models TWDXCAT3RJ and TWDXCAISO.

External power supply for TWDXCAISO only : 24Vdc / 80mA.

**Note:**

Open type devices are Certified as components for use only in other Certified equipment where the suitability of the combination is to be determined by CSA International.

**PART B:**

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT – For Hazardous Locations

Class I Division 2 Groups A, B, C and D, max. ambient 60°C, Temperature Code T4A

Models TWDXCAT3RJ and TWDXCAISO.

External power supply for TWDXCAISO only : 24Vdc / 80mA

**Note:**

Open type devices are Certified as components for use only in other Certified equipment where the suitability of the combination is to be determined by CSA International.

**APPLICABLE REQUIREMENTS**

CSA C22.2 No 0.4-04 Bonding & Grounding of Electrical Equipment (Protective Grounding)

CSA C22.2 No.142-M1987 Process Control Equipment

CSA C22.2 No.213-M1987 Non-incendive Electrical Equipment for use in Class I Division 2 Hazardous Locations