

Certificate of Compliance

Certificate: 2465317

Master Contract: 225619

Project: 2504430

Date Issued: March 19, 2012

Issued to: Telemecanique/Schneider Electric

Industries SAS.

BP 660

Zone Industrielle No. 3

L'Isle d'Espagnac, 16340

France

Attention: Mr. Jean-Pierre Laidet

The products listed below are eligible to bear the CSA Mark shown



J.-C. Chow

Issued by: J.-C. Chow

PRODUCTS

CLASS 3211 03 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices

- Push-buttons, 22 mm line, Cat. No. XB7-NA, -NH or -NL, and Selector switches, Cat. No. XB7-ND or -NG, rated D300, R300. Suitable for enclosure Type 12.
- Illuminated push-buttons, 22 mm line, Cat. No. XB7-NW or -NJ, direct supply (incandescent or neon), rated 250Vac max, 50/60Hz, 1.2W max, or integral LED, rated 24Vac/dc-25mA, 120Vac-15mA, or 230Vac-27mA, 50/60Hz. Suitable for enclosure Type 12.
- Emergency Stop Push-buttons, 22 mm line, Cat. No. XB7-NS or -NT, rated C300, R300. Suitable for enclosure Type 3 or 12.

Notes:

1. Cat. No. is followed by suffixes designating supply voltage, contacts, markings and colour options.
2. These open type devices are certified for use in other Certified equipment where the suitability of the combination is determined by CSA International.

APPLICABLE REQUIREMENTS

CSA-C22.2 No.14-10 - Industrial Control Equipment



Certificate: 2465317

Master Contract: 225619

Project: 2504430

Date Issued: March 19, 2012

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures