

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)  
CB SCHEME**
**CB TEST CERTIFICATE**

Product

Buzzer and Illuminated Buzzer

Name and address of the applicant

Schneider Electric Industries SAS  
35 rue Joseph Monier Rueil Malmaison, 92500  
France

Name and address of the manufacturer

Schneider Electric Industries SAS,  
Boulevard Salvador Allende, BP 660, 16340 L'isle D'espagnac  
France

Name and address of the factory

PT. Schneider Electric Manufacturing Batam  
Batam Industrial Park, Blk 1, 4 & 208, Mukakuning, Batam  
Indonesia

*Note: When more than one factory, please report on page 2*
☐ Additional Information on page 2

Ratings and principal characteristics

See Page 2

Trademark (if any)

Schneider Electric

Type of Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

XB5KS  
See Page 2

Additional information (if necessary may also be reported on page 2)

Additionally evaluated to EN 60947-1:2007/A1:2011 and  
EN 60947-5-1:2017.  
National Differences specified in the CB Test Report.

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-1(ed.5), IEC 60947-1(ed.5);am1, IEC 60947-5-1(ed.4)

As shown in the Test Report Ref. No. which forms part of this Certificate

4788189445 issued on 2018-02-06

This CB Test Certificate is issued by the National Certification Body



UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA

UL (Denko), Borupvang 5A DK-2750 Ballerup, DENMARK

UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN

UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see [www.ul.com/ncbnames](http://www.ul.com/ncbnames)

Date: 2018-02-27

Signature:

Jan-Erik Storgaard

Model Details:

XB5KS may be followed by 2, followed by B, G or M, may be followed by 4 or 8.

Ratings:

Electrical : PD3 OVC III AC/DC 50/60Hz

Type Ue/Ui = Ie / Ith =

Non illuminated 24 V ac/dc Max 28mA

Non illuminated 110-120 V ac/dc Max 20mA

Non illuminated 230-240 V ac Max 18mA

Illuminated 24 V ac/dc Max 58mA

Illuminated 110-120 V ac/dc Max 20mA

Illuminated 230-240 V ac Max 35mA

Mounting nut, torque 2.2 Nm

Field wiring : 22 – 16 AWG str.

IP : IP66, IP67

Additional information (if necessary)



UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA

UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK

UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN

UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see [www.ul.com/nbnames](http://www.ul.com/nbnames)

Date: 2018-02-27

Signature:

Jan-Erik Storgaard