

Downloads

EGX300 Firmware & Disk Image Update

Version 4.461 firmware updates:

- Address issue where the BCPM/BCM Circuit/Channel Names were not saved after power cycle
- Address issue where Custom Devices are lost upon upgrade to disk 4.450 version

Version 4.460 Disk Update provides:

- Updated PM5000 Energy Values
- Updated Sepam 40 Trending
- Updated Micrologic H Real Time View

*Upgrading to version 4.461 requires new firmware to be downloaded to the EGX followed by the egx04460.upd Disk Image.

Firmware Download Instructions for EGX300 Currently Running Firmware Version 3.7xx

Updating to version 4.461 from version 3.7xx requires all data log files to be converted internally. This conversion will be executed at the first boot after the download. While converting the data log files, browsing of the EGX will be limited to a page displaying the status of the conversion until conversion is complete. Depending on the size and number of the data log files, this process may take several minutes.

Before downloading the firmware, logging must be disabled. It is recommended the user save all data log files to external storage before downloading. Refer to the EGX300 User's Guide for instructions on how to disable logging and remove data log files.

1. Disable Logging.
2. Save data log files to external storage (optional but recommended).
3. Remove data log files (optional but recommended).
4. Transfer the version 4.461 firmware file (egx04461.bin) to your computer.
5. Use FTP to copy the "egx04461.bin" file from your computer to the EGX300. The status LED will flash rapidly while the firmware is being programmed. **Do not remove power during this time.** Once the download is complete the EGX will automatically reboot. Refer to the EGX300 User's Guide if you need more information.
6. Allow the EGX to reboot after the firmware file transfer, then browse the EGX300 Diagnostic Statistics page and confirm V4.461 is displayed as the Firmware Version in the Gateway Information section.
7. After confirming the firmware has been updated apply the V4.460 Disk Update.

Firmware Download Instructions for EGX300 Currently Running Firmware Version 3.800 or Greater

Before downloading the v4.461 firmware, it is recommended to disable logging and to save all data log files to external storage. Refer to the EGX300 User's Guide for instructions on how to disable logging and remove data log files.

1. Disable Logging.
2. Save data log files to external storage (optional but recommended).
3. Remove data log files (optional but recommended).
4. Transfer the version 4.461 firmware file (egx04461.bin) to your computer.
5. Use FTP to copy the "egx04461.bin" file from your computer to the EGX. The status LED will flash rapidly while the firmware is being programmed. **Do not remove power during this time.** Once the download is complete, the EGX will automatically reboot. Refer to the EGX300 User's Guide if you need more information.
6. Allow the EGX to reboot after the firmware file transfer then browse the EGX300 Diagnostic Statistics page and confirm 4.461 is displayed as the Firmware Version in the Gateway Information section.
7. After confirming the firmware has been updated apply the V4.460 Disk Update.