

CERTIFICATE OF COMPLIANCE

Certificate Number 20150202-E63335
Report Reference E63335-20110610
Issue Date 2015-FEBRUARY-02

Issued to: SCHNEIDER ELECTRIC INDUSTRIES S A S
ELECTROPOLE/EYBENS, POWER / LV
31 RUE PIERRE MENDES FRANCE
38050 GRENOBLE CEDEX 9 FRANCE


This is to certify that representative samples of CIRCUIT BREAKERS, MOLDED CASE AND CIRCUIT-BREAKER ENCLOSURES
(See following page for additional information.)

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 489, "Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures."

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20150202-E63335
Report Reference E63335-20110610
Issue Date 2015-FEBRUARY-02

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Additional Information:

Molded case circuit breakers POWERPACT L with prefix LD, LG, LJ, LL, LR or NLD, NLG, NLJ, NLL, NLR rated 250A, 400 A and 600 A, 600 V ac, 3 and 4 poles.

Molded case circuit breakers POWERPACT L for UPS application with suffix LG and LL rated 600A maximum frame rating for 3P 1200A maximum frame rating for 2P and voltage rating of 500 Vdc.

Square D - Type LD, LG, LJ, LL, LR

Schneider Electric - Type NLD, NLG, NLJ, NLL, NLR



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

