



Certificate of Compliance

Certificate: 70089262

Master Contract: 177007 (LR 69561)

Project: 70089262

Date Issued: 2016-08-25

Issued to: Schneider Electric Industries SAS
Power Business Unit / LV
31, rue Pierre Mendes France
Eybens
Grenoble Cedex 9, 38050
FRANCE
Attention: Laurent Yvroud

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Ronald Tateishi*
Ronald Tateishi

PRODUCTS

CLASS 1432 01 - CIRCUIT BREAKERS - Moulded Case Type

Moulded case circuit breakers, Powerpact BD, BG and BJ, 1-, 2-, 3- and 4- pole, 125A max, 600Y/347V ac max for 2-, 3- and 4-pole and 347V ac max for 1-pole.

Moulded case circuit breakers, Powerpact BK, 1- and 2-pole, 30A max, 600Y/347V ac max for 2-pole and 347V ac max for 1-pole.

Notes:

1. These circuit breakers may be line-load reverse connected.
2. The unit mount and I-Line circuit breakers rated 60A maximum are suitable for used at 100 percent rating. The 100 percent rating requires the use of the copper 90°C rated mechanical lugs or the aluminum 90°C rated mechanical lugs or the compression lug in copper or aluminum 90°C rated lugs.
3. 15 and 20A circuit breakers are suitable for switching 347V ac max fluorescent lighting loads and may be marked "SWD".
4. 30A max circuit breakers are suitable for switching 347V ac max high-intensity-discharge lighting loads and may be marked "HID".



Certificate: 70089262

Master Contract: 177007 (LR 69561)

Project: 70089262

Date Issued: 2016-08-25

5. These circuit breakers may be marked with interrupting ratings as follows:

Circuit Breaker Type	S.C. Interrupting Rating (kA, rms, sym)			
	D	G	J	K*
240Vac, 1Ø-3Ø **	18	35	65	-
240V ac	25	65	100	100
480Y/277V ac	18	35	65	65
480V ac***	18	35	65	65
600Y/347V ac	14	18	25	65

* Applies only to 1- and 2-pole constructions, 15 to 30A.

**Applies only to the 2-pole construction.

*** Applies to the 2-, 3- and 4-pole constructions

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures.



Supplement to Certificate of Compliance

Certificate: 70089262

Master Contract: 177007 (LR 69561)

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70089262	2016-08-25	Original Certification.