

Certificate of Compliance

Certificate: 1545090 (LR 96921) **Master Contract:** 224330

Project: 70008672 Date Issued: September 24, 2014

Issued to: Schneider Toshiba Inverter SAS

32 rue Andre Blanchet Pacy sur Eure, 27120

France

Attention: Frédéric Roussel

The products listed below are eligible to bear the CSA Mark shown



Pierre-Yves Despatis

Issued by: Pierre-Yves Despatis

PRODUCTS

CLASS 3211 06 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers -

Miscellaneous

Solid state reduced voltage starters, Type ATS01N followed by suffixes, open type, line voltage 600V ac max, 1 or 3 ph, 50/60Hz, 75 hp max, 85A max continuous current, soft stop function is only provided with Type ATS01N2...

APPLICABLE REQUIREMENTS

CSA-C22.2 No. 14-13 - Industrial Control Equipment

CSA C22.2 No. 274-13 - Adjustable speed drives

DQD 507 Rev. 2012-05-22 Page: 1