



中国国家强制性产品认证证书

证书编号: 2011010305517972

委托人名称、地址

Schneider Electric Asia Pte Ltd
50 Kallang Avenue, Singapore 339505

生产者(制造商)名称、地址

PT. Schneider Electric Manufacturing Batam
Jl Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka
Kuning Kel.Muka Kuning Kec. Sungai Beduk - Batam, Indonesia

生产企业名称、地址

PT. Schneider Electric Manufacturing Batam
Jl Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka
Kuning Kel.Muka Kuning Kec. Sungai Beduk - Batam, Indonesia

产品名称和系列、规格、型号

急停开关

XB7N: Ui:250V;Uimp:6kV;AC-15:Ue/Ie:AC240V/1.5A, AC120V/3A;Ith:5A;外壳防护等级:IP65(安装面板之前), IP20(安装面板之后);安装孔径 Φ : 22.0mm;型号解释见附件

产品标准和技术要求

GB/T14048.5-2017

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求,
特发此证。

发证日期: 2019 年 05 月 30 日 有效期至: 2021 年 12 月 20 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2011 年 12 月 20 日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:

陆楠



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2011010305517972

NAME AND ADDRESS OF THE APPLICANT

Schneider Electric Asia Pte Ltd
50 Kallang Avenue, Singapore 339505

NAME AND ADDRESS OF THE MANUFACTURER

PT. Schneider Electric Manufacturing Batam
Jl Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka Kuning Kel.Muka Kuning
Kec. Sungai Beduk – Batam, Indonesia

NAME AND ADDRESS OF THE FACTORY

PT. Schneider Electric Manufacturing Batam
Jl Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka Kuning Kel.Muka Kuning
Kec. Sungai Beduk – Batam, Indonesia

PRODUCT NAME, MODEL AND SPECIFICATION

Emergency Stop Switch

XB7N: Ui:250V;Uimp:6kV;AC-15:Ue/Ie:AC240V/1.5A, AC120V/3A;Ith:5A;IP65 (before installing the panel) , IP20 (After installing the panel) ; Mounting apertureΦ: 22.0mm

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.5-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: May.30,2019

Valid until: Dec.20,2021

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Dec.20,2011

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附 录

第 1 页 共 1 页

证书编号: 2011010305517972

纸 号: 2280168

型号解释:

1. 急停开关 (旋转复位) Emergency Stop Switch (Twist to Release)

.XB7 NS .8. .4. .4. .2.
I II III IV V

I - 产品系列号及基本功能 Designate the series and the function

XB7 NS: 旋转复位 Twist to Release

II - 操作头描述 Description of Head

8- 旋转复位 Turn to Release trigger action

9- 钥匙复位 Key Release trigger action

III - 操作头直径 Diameter of the head

4 - 40mm

IV - 操作头颜色 Color of the Head

4 - 红色 Red

V - 触头类型 Contacts

2 - N/C

4 - N/C + N/C

5 - N/C + N/O

2. 急停开关 (拉拔复位) Emergency Stop Switch (Pull to Release)

.XB7 NT .8. .4. .2.
I II III IV

I - 产品系列号及基本功能 Designate the series and the function

XB7 NT: 拉拔复位 Pull to Release

II - 操作头描述 Description of Head

8- 拉拔复位/操作头直径 40mm Push Pull trigger action 40mm diameter

III - 操作头颜色 Color of the Head

4 - 红色 Red

IV - 触头类型 Contacts

2 - N/C

4 - N/C + N/C

5 - N/C + N/O

注: 此附录与证书同时使用时有效。



主 任:

陆梅



中国质量认证中心