



NOTES:

1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE LOCAL AND NATIONAL CODES..
2. PLEASE REFER TO PRODUCT MANUALS FOR ADDITIONAL DETAILS.
- △ 3. UTILITY SOURCE MUST BE 208/240VAC (2PH+G) 50/60Hz 1PH PROVIDED BY OTHERS.
- △ 4. DASHED LINES BETWEEN UNITS (- - -) REPRESENT CABLING PROVIDED BY OTHERS.
- △ 5. ADDITIONAL EXTERNAL BATTERY PACKS, (UPTO 10) CAN BE CONNECTED TO INCREASE THE RUN TIME FURTHER.
- △ 6. REFER TO INSTALLATION MANUAL FOR DETAILED INSTRUCTIONS ON WIRING INPUT TRAY.
- △ 7. REFER TO INSTALLATION MANUAL FOR DETAILED INSTRUCTIONS ON WIRING OUTPUT TRAY.
- △ 8. PDU PANELS ARE MOUNTED ON THE REAR OF THE BATTERY PACK. OTHER, OPTIONAL, PDU PANELS CAN BE PURCHASED SEPARATELY AND INSTALLED TO PROVIDE ALTERNATIVE LOAD CONNECTIONS.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.



TITLE: Smart-UPS On-Line
 INPUT: 208/240VAC (2PH+G) 50/60Hz 1PH
 OUTPUT: 208/240VAC (2PH+G) 50/60Hz 1PH
 SYSTEM ONE LINE DIAGRAM

PROJECT: SUBMITTAL DRAWINGS SHEET 1 OF 1

DWG NO: SURT20KRMXLT-SD

ENGINEER: V.CHENNAKESAVAN 23-SEP-09

APPROVED: J.PRECOPIO 23-SEP-09

REV. 0

ANGLE

PROJECTION

N.A.