



中国国家强制性产品认证证书

证书编号: 2011010305520487

委托人名称、地址

Schneider Electric Asia Pte Ltd
50 Kallang Avenue, Singapore 339505

生产者(制造商)名称、地址

PT. Schneider Electric Manufacturing Batam
Jl Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka
Kuning Kel.Muka Kuning Kec. Sungai Beduk - Batam, Indonesia

生产企业名称、地址

PT. Schneider Electric Manufacturing Batam
Jl Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka
Kuning Kel.Muka Kuning Kec. Sungai Beduk - Batam, Indonesia

产品名称和系列、规格、型号

按钮开关

XB7NA, XB7NL, XB7NH, XB7NW, XB7NJ, XB7ND, XB7NG: Ui:250V;Uimp:4kV;AC-14:Ue/Ie:AC240V/0.3A,
AC120V/0.6A;Ith:2A;外壳防护等级:IP65;安装孔径 Φ :22.5mm;带灯按钮:白炽
灯:AC250Vmax,50/60Hz;LED:AC230V,50/60Hz,AC120V,50/60Hz; 型号解释见附件

产品标准和技术要求

GB/T14048.5-2017

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求,
特发此证。

发证日期: 2019 年 08 月 15 日 有效期至: 2022 年 01 月 09 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2012 年 01 月 09 日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:

陆梅



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2011010305520487

NAME AND ADDRESS OF THE APPLICANT

Schneider Electric Asia Pte Ltd
50 Kallang Avenue, Singapore 339505

NAME AND ADDRESS OF THE MANUFACTURER

PT. Schneider Electric Manufacturing Batam
Jl Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka Kuning Kel.Muka Kuning Kec.
Sungai Beduk – Batam, Indonesia

NAME AND ADDRESS OF THE FACTORY

PT. Schneider Electric Manufacturing Batam
Jl Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka Kuning Kel.Muka Kuning Kec.
Sungai Beduk – Batam, Indonesia

PRODUCT NAME, MODEL AND SPECIFICATION

Pushbutton Switch

XB7NA, XB7NL, XB7NH, XB7NW, XB7NJ, XB7ND, XB7NG: Ui:250V;Uimp:4kV;AC-14:Ue/Ie:AC240V/0.3A, A
C120V/0.6A;Ith:2A;IP65;Mounting aperture: Φ :22.5mm;Button with lamp: incandescent lamp:AC250V/max,50/
60Hz;LED:AC230V,50/60Hz,AC120V,50/60Hz

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.5-2017

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Aug.15,2019

Valid until: Jan.09,2022

The validity of the certificate is subject to positive result of the regular follow up inspection by
issuing certification body until the expiry date.

Date of original issued: Jan.09,2012

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附录

第 1 页 共 2 页

证书编号: 2011010305520487

纸 号: 2352926

型号解释:

NOMENCLATURE 命名法:

Cat. No. XB7N $\frac{1}{I}$ $\frac{1}{II}$ $\frac{2}{III}$ $\frac{2}{IV}$ $\frac{P}{V}$ $\frac{3}{VI}$

	I	II	III	IV	V	VI
Spring return push button 弹力恢复式按钮	XB7NA					
Latching push button 自锁式按钮	XB7NH					
Projecting push button 凸出式按钮	XB7NL					
White 白		1				
Black 黑		2				
Green 绿		3				
Red 红		4				
Yellow 黄		8				
Blue 蓝		6				
N/O			1			
N/C			2			
N/O + N/O			3			
N/C + N/C			4			
N/C + N/O			5			

注: 此附录与证书同时使用时有效。



主 任:

陆梅



中国质量认证中心



中国国家强制性产品认证证书

附录

第 2 页 共 2 页

证书编号: 2011010305520487

纸号: 2352926

Optional 可选择:					
Marking 标志 "I"				31	
Marking 标志 "II"				36	
Marking 标志 "O"				32	
Marking 标志 "ARRET" or 或者 "START"				33	
Marking 标志 "STOP"				34	
Marking UP arrow 标志 向上箭头				341	
Marking RIGHT arrow 标志 向右箭头				342	
Marking DOWN arrow 标志 向下箭头				343	
Marking LEFT arrow 标志 向左箭头				344	
Marking 标志 "MARCHE"				42	
Handle operated selector 手柄操作式开关	XB7ND				
Key operator 钥匙操作式开关	XB7NG				
Two maintained positions 2 个固定位		2			
Three maintained positions 3 个固定位		3			
N/O			1		
N/O + N/O			3		
N/C + N/O			5		
Spring return illuminated push button 弹力恢复式带指示器的按钮开关	XB7NW3				
Latching illuminated push button 自锁式带指示器的按钮开关	XB7NJ0				
Green 绿		3			
Red 红		4			
Yellow 黄		8			
Blue 蓝		6			
Orange 橙		5			
Clear 透明		7			
Direct supply, for incandescent bulb, 250 V maximum 直接供电、白炽灯、最大电压 250 V			6		
Supply of LED models LED 型号的电					
110 V ac			G		
230 V ac			M		
N/O				1	
N/C				2	

注: 此附录与证书同时使用时有效。



主任:

陆梅



中国质量认证中心