



Certificate of Compliance

Certificate: 2155978

Master Contract: 225619

Project: 2589421

Date Issued: December 21, 2012

Issued to: Telemecanique/Schneider Electric

Industries SAS.

BP 660

Zone Industrielle No. 3

L'Isle d'Espagnac, 16340

France

Attention: Mr. Jean-Pierre Laidet

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



J.-C. Chow

Issued by: J.-C. Chow

PRODUCTS

CLASS 3211 83 - INDUSTRIAL CONTROL EQUIPMENT-Motor Controllers - Auxiliary Devices-Certified to U.S. Standards

CLASS 3211 03 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices

Biometric switch, fingerprint reader, open type, Cat. No. XB5 S, followed by 1, 2, 3, 4 or 5, followed by B, followed by 2, followed by L with a number or followed by M12; rated 24 Vdc supply, 200 mA PNP-output, resistive, protected against overload and short-circuit; enclosure Type 12.

Notes:

- 1) These open type devices are certified for use in other Certified equipment where the suitability of the combination is to be determined by CSA International.
- 2) Non-evaluated as a biometric operating device where its suitability within the en-use application shall require further evaluation should this feature be considered critical for safety.

APPLICABLE REQUIREMENTS



Certificate: 2155978

Master Contract: 225619

Project: 2589421

Date Issued: December 21, 2012

CSA-C22.2 No. 14-10 - Industrial Control Equipment

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures

ANSI/UL 508 (17th Edition) - Industrial Control Equipment

ANSI/UL 50E (1st Edition) - Enclosures for Electrical Equipment, Environmental Considerations.