

### Main

Device application	Coronary/Intensive care Operating room
--------------------	-------------------------------------------

### Complementary

Line Rated Current	20 A QO220 2P 8), secondary circuit 20 A, primary circuit
Device composition	XR29420 trim panel
Device mounting	53015BB flush mounting box 53019BB surface mounting box
Mounting support	wall
Phase	1 phase
Output voltage	120 V
Primary voltage	480 V
Rated power in VA	7.5 kVA
Secondary voltage	120 V
Supply	7XR51 via mains transformer to be ordered separately

### Environment

Product certifications	UL Listed
------------------------	-----------

### Ordering and shipping details

Category	16001 - O.R. PANELS NON STOCK
Discount Schedule	O1
GTIN	00785901156765
Package weight(Lbs)	50 lb(US) (22.68 kg)
Returnability	No
Country of origin	US

### Contractual warranty

Warranty	18 months
----------	-----------