



中国国家强制性产品认证证书

证书编号: 2008010304269738

委托人名称、地址

上海施耐德工业控制有限公司
上海市普陀区绥德路 629 号

生产者(制造商)名称、地址

SCHNEIDER ELECTRIC INDUSTRIES SAS

35, rue Joseph Monier - CS 30323 - 92506 Rueil-Malmaison - FRANCE

生产企业名称、地址

Schneider Electric Industries S. A.
ZAC Le Village Le Vaudreuil - 27100 - France

产品名称和系列、规格、型号

交流接触器

LC1D40A, LC2D40A, LC1D50A, LC2D50A, LC1D65A, LC2D65A, LC1D80A, LC2D80A,
LC1DT60A, LC1DT80A; 详见附件

产品标准和技术要求

GB/T14048. 4-2010

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求,
特发此证。

发证日期: 2018 年 08 月 02 日 有效期至: 2022 年 03 月 06 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2008 年 03 月 25 日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2008010304269738

NAME AND ADDRESS OF THE APPLICANT

Schneider Shanghai Industrial Control Co., Ltd.
No.629 Suide Road, Putuo District, Shanghai, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

SCHNEIDER ELECTRIC INDUSTRIES SAS
35, rue Joseph Monier - CS 30323 - 92506 Rueil-Malmaison - FRANCE

NAME AND ADDRESS OF THE FACTORY

Schneider Electric Industries S. A.
ZAC Le Village Le Vaudreuil - 27100 - France

PRODUCT NAME, MODEL AND SPECIFICATION

AC Contactor

LC1D40A, LC2D40A, LC1D50A, LC2D50A, LC1D65A, LC2D65A, LC1D80A, LC2D80A,
LC1DT60A, LC1DT80A; See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.4-2010

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Aug.02,2018

Valid until: Mar.06,2022

The validity of the certificate is subject to positive result of the regular follow up
inspection by issuing certification body until the expiry date.

Date of original issued: Mar.25,2008

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附录

第 1 页 共 9 页

证书编号: 2008010304269738

纸 号: 2018656

LC1D40A, LC2D40A, LC1D50A, LC2D50A, LC1D65A, LC2D65A, LC1D80A, LC2D80A,
LC1DT60A, LC1DT80A

Uimp: 6kV

Ui: 690V

LC1D40A, LC2D40A:

AC-1: Ue/Ie: 230/400/440/500/690V/60A;

AC-3: Ue/Ie: 230V/38A, 400V/35A, 440V/40A, 500V/33A, 690V/32A;

AC-4: Ue/Ie: 230V/38A, 400V/35A, 440V/40A, 500V/33A, 690V/21A;

Ith: 60A ;

3P;

LC1D50A, LC2D50A:

AC-1: Ue/Ie: 230/400/440/500/690V/80A;

AC-3: Ue/Ie: 230V/51A, 400V/41A, 440V/50A, 500V/44A, 690V/35A;

AC-4: Ue/Ie: 230V/51A, 400V/41A, 440V/50A, 500V/33A, 690V/21A;

Ith: 80A ;

3P ;

LC1D65A, LC2D65A:

AC-1: Ue/Ie: 230/400/440/500/690V /80A;

AC-3: Ue/Ie: 230V/61A, 400V/55A, 440V/65A, 500V/53A, 690V/39A;

AC-4: Ue/Ie: 230V/61A, 400V/55A, 440V/50A, 500V/33A, 690V/21A;

Ith: 80A;

3P;

LC1D65A6BDS304:

AC-1: Ue/Ie: 230/400/440/500/690V /91A;

AC-3: Ue/Ie: 230V/61A, 400V/55A, 440V/65A, 500V/53A, 690V/39A;

AC-4: Ue/Ie: 230V/61A, 400V/55A, 440V/50A, 500V/33A, 690V/21A;

Ith: 91A; (50° C)

注: 此附录与证书同时使用时有效。



主 任:



中国质量认证中心



中国国家强制性产品认证证书

附 录

第 2 页 共 9 页

证书编号: 2008010304269738

纸 号: 2018656

3P;

LC1D80A, LC2D80A:

AC-1: U_e/I_e : 230/400/440/500/690V /80A;

AC-3: U_e/I_e : 230V/80A, 400V/80A, 440V/65A, 500V/53A, 690V/39A;

AC-4: U_e/I_e : 230V/61A, 400V/55A, 440V/50A, 500V/33A, 690V/21A;

I_{th} : 80A;

3P;

LC1DT60A:

AC-1: U_e/I_e : 230/400/440/500/690V /60A;

I_{th} : 60A ;

4P;

LC1DT80A:

AC-1: U_e/I_e : 230/400/440/500/690V /80A;

I_{th} : 80A ;

4P;

Us:

50Hz: AC12V, 24V, 42V, 48V, 230V;

60Hz: AC24V;

50/60Hz: AC24V, 32V, 42V, 48V, 100V, 110V, 115V, 120V, 127V, 200V, 208V,

220V, 230V, 240V, 277V, 380V, 400V, 415V, 440V, 480V, 500V,

575V, 600V, 660V, 690V;

DC: 12V, 24V, 36V, 48V, 60V, 72V, 110V, 125V, 220V, 250V, 440V;

电子式线圈:

DC: 24V;

50Hz/60Hz/DC: 24-60V, 48-130V, 100-250V.

配用的辅助触头: (本体)

I_{th} : 10A;

注: 此附录与证书同时使用时有效。



主 任:



中国质量认证中心



中国国家强制性产品认证证书

附 录

证书编号: 2008010304269738

第 3 页 共 9 页

纸 号: 2018656

AC-15: U_e/I_e : 120V/6A, 690V/1.04A;

DC-13: U_e/I_e : 125V/1.1A, 600V/0.2A;

弹簧卡接线:

I_{th} : 10A;

AC-15: U_e/I_e : 120V/6A, 400V/1.8A;

DC-13: U_e/I_e : 125V/1.1A, 250V/0.55A

外壳防护等级: IP10

1N01NC

注: 此附录与证书同时使用时有效。



主 任:



中国质量认证中心



中国国家强制性产品认证证书

附录

第 4 页 共 9 页

证书编号: 2008010304269738

纸 号: 2018656

型号解释:

LC1	D65	A	6	—	BD	S304
I	II	III	IV	V	VI	VII

I	产品型号 LC1: 单个接触器 LC2: 可逆接触器
II	规格 D40 (3 极) D50 (3 极) D65 (3 极) D80 (3 极) (不适用直流线圈产品) DT60 (4 极) (不适用电子线圈产品) DT80 (4 极) (不适用电子线圈产品)
III	产品族说明 A: Tesys 系列接触器
IV	接线型式: (主电路 / 控制电路) 空白: 提升式螺钉/螺钉 3: 提升式螺钉/ 弹簧卡 (不适用电子线圈产品) 6: 环型接线片/环型接线片
V	前盖 空白: 标准型 (带前盖) 5: 不带可移前盖
VI	线圈电压代码 见下表:
VII	后缀 空白: 常规产品 S304: 此后缀 S304 仅适用于 LC1D65A6BDS304

注: LC1D65A6BDS304 与 LC1D65A6BD 完全等同, 除了宣称 $I_{th}=91A(50^{\circ}C)$, $I_e(AC-1)=91A$ 。

注: 此附录与证书同时使用时有效。



主 任:



中国质量认证中心



中国国家强制性产品认证证书

附录

第 5 页 共 9 页

证书编号: 2008010304269738

纸 号: 2018656

交流线圈:

代码	Us(V)	频率	代码	Us(V)	频率
J5	12	50 Hz	E5 (*)	48	50Hz
B5 (*)	24	50Hz	P5 (*)	230	50Hz
D5 (*)	42	50Hz	P7	230	50 / 60Hz
B6	24	60Hz	U7	240	50 / 60Hz
B7	24	50 / 60Hz	W7	277	50 / 60Hz
C7	32	50 / 60Hz	Q7	380	50 / 60Hz
D7	42	50 / 60Hz	V7	400	50 / 60Hz
E7	48	50 / 60Hz	N7	415	50 / 60Hz
K7	100	50 / 60Hz	R7	440	50 / 60Hz
F7	110	50 / 60Hz	T7	480	50 / 60Hz
FE7	115	50 / 60Hz	S7	500	50 / 60Hz
G7	120	50 / 60Hz	SC7	575	50 / 60Hz
FC7	127	50 / 60Hz	X7	600	50 / 60Hz
L7	200	50 / 60Hz	YC7	660	50 / 60Hz
LE7	208	50 / 60Hz	Y7	690	50 / 60Hz
M7	220	50 / 60Hz			

直流线圈:

代码	Us(V)	频率
JD	12	DC
BD	24	DC
CD	36	DC
ED	48	DC
ND	60	DC
SD	72	DC
FD	110	DC
GD	125	DC
MD	220	DC
UD	250	DC
RD	440	DC

注: 此附录与证书同时使用时有效。



主 任:



中国质量认证中心



中国国家强制性产品认证证书

附 录

第 6 页 共 9 页

证书编号: 2008010304269738

纸 号: 2018656

电子式线圈:

线圈代码	Us (V)	频率
BBE	24	dc
BNE	24-60	50/60Hz and dc
EHE	48-130	50/60Hz and dc
KUE	100-250	50/60Hz and dc

(*) 注: 以上 B5, D5, E5, P5 线圈除了额定频率标称和标牌, 分别与 B7, D7, E7, P7 线圈完全等同。

注: 此附录与证书同时使用时有效。



主 任:



中国质量认证中心



中国国家强制性产品认证证书

附录

第 7 页 共 9 页

证书编号: 2008010304269738

纸号: 2018656

LC1	D65	A	6		BD	S304
I	II	III	IV	V	VI	VII

I	Product type LC1: Single contactor LC2: Reversing contactor
II	Size D40 (3 poles) D50 (3 poles) D65 (3 poles) D80 (3 poles) not provided with dc coils DT60 (4 poles) not provided for electronic ac/dc coils DT80 (4 poles) not provided for electronic ac/dc coils
III	Indication A: Tesys contactor range
IV	Type of connection: (Power / Control) Blank: "Everlink" Connector / screws 3: "Everlink" Connector / spring connections: not provided for electronic ac/dc coils 6: Ring lugs Connector / Ring lugs Connector
V	Indicates front cover presence Blank: Standard treatment (with cover) 5: without removable front cover
VI	Indicates Coil Voltage Code See table below:
VII	Postfix Blank: for normal products S304: Postfix S304 is only applicable for LC1D65A6BDS304

Note: LC1D65A6BDS304 is fully identical to LC1D65A6BD except the declared value $I_{th}=91A(50^{\circ}C)$, $I_e(AC-1)=91A$.

注: 此附录与证书同时使用时有效。



主任:



中国质量认证中心



中国国家强制性产品认证证书

附 录

第 8 页 共 9 页

证书编号: 2008010304269738

纸 号: 2018656

AC coil :

Coil code	Us(V)	Frequency	Coil code	Us(V)	Frequency
J5	12	50 Hz	E5 (*)	48	50Hz
B5 (*)	24	50Hz	P5 (*)	230	50Hz
D5 (*)	42	50Hz	P7	230	50 / 60Hz
B6	24	60Hz	U7	240	50 / 60Hz
B7	24	50 / 60Hz	W7	277	50 / 60Hz
C7	32	50 / 60Hz	Q7	380	50 / 60Hz
D7	42	50 / 60Hz	V7	400	50 / 60Hz
E7	48	50 / 60Hz	N7	415	50 / 60Hz
K7	100	50 / 60Hz	R7	440	50 / 60Hz
F7	110	50 / 60Hz	T7	480	50 / 60Hz
FE7	115	50 / 60Hz	S7	500	50 / 60Hz
G7	120	50 / 60Hz	SC7	575	50 / 60Hz
FC7	127	50 / 60Hz	X7	600	50 / 60Hz
L7	200	50 / 60Hz	YC7	660	50 / 60Hz
LE7	208	50 / 60Hz	Y7	690	50 / 60Hz
M7	220	50 / 60Hz			

DC coil :

Coil code	Us(V)	Frequency
JD	12	DC
BD	24	DC
CD	36	DC
ED	48	DC
ND	60	DC
SD	72	DC
FD	110	DC
GD	125	DC
MD	220	DC
UD	250	DC
RD	440	DC

注: 此附录与证书同时使用时有效。



主 任:



中国质量认证中心



中国国家强制性产品认证证书

附 录

证书编号: 2008010304269738

第 9 页 共 9 页

纸 号: 2018656

Electronic coils:

Coil code	Us (V)	Frequency
BBE	24	dc
BNE	24-60	50/60Hz and dc
EHE	48-130	50/60Hz and dc
KUE	100-250	50/60Hz and dc

(*) Note : a.m. B5, D5, E5 and P5 referenced coils are respectively identical to B7, D7, E7 and P7 ones except for rated frequency and markings.

注: 此附录与证书同时使用时有效。



主 任:



中国质量认证中心