



Certificate of Compliance

Certificate: 2304490

Master Contract: 240515

Project: 2565374

Date Issued: November 14, 2012

Issued to: Telemecanique/Schneider Electric
Industries SAS
Zone Industrielle No. 3
L'Isle d'Espagnac, 16340
France
Attention: Mr. Christophe Delaître

The products listed below are eligible to bear the CSA Mark shown



J.-C. Chow

Issued by: J.-C. Chow

PRODUCTS

CLASS 3211 03 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices

Key-operated limit switches, Cat. Nos. XCS-LE and XCS-LF, followed by a six-digit number, followed by 2, 3, M2 or M3, may be followed by a two digit number; rated:

- Supply/Electromagnet voltage: 24 Vac/dc or 120 Vac or 230Vac
- Output: Pilot duty, C300, R300; except for models with suffix M2 or M3: 24 Vac, 1.5 A and 24 Vdc, 0.22 A
- Enclosure Type: 4/4X or 12, for model Cat. No. XCS-LF (metallic housing); 4X (indoor use only) or 12, for model Cat. No. XCS-LE (polymeric housing)

APPLICABLE REQUIREMENTS

CSA-C22.2 No. 14-10 - Industrial Control Equipment

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures