

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	EMERGENCY STOP DEVICE (PUSH BUTTON SWITCH)
Name and address of the applicant	Schneider Electric Industries SAS 35 Rue Joseph Monier Rueil Malmaison, 92500 France
Name and address of the manufacturer	Schneider Electric Industries SAS / Laboratoire L2A Boulevard Salvador Allende BP 660 L'isle D'espagnac, 16340 France
Name and address of the factory	Schneider Electric France Zone industrielle, BP 660 F16340 L'Isle d'Espagnac France
<p><i>Note: When more than one factory, please report on page 2</i></p>	<input checked="" type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	Utilization category : AC15 - DC13 A600 - Q600 - A300 - Q300 - R300 - P300 - B300 Resistive Protection degree : 66 (front, all) 67 (front, only for ZB5AS84W, XALK84W, XALK178W series) 20 (back, all) See test report 4788731990B for complete detailed ratings.
Trademark (if any)	Schneider Electric
Type of Customer's Testing Facility (CTF) Stage used	CTF Stage 3
Model / Type Ref.	XALK178 Series, XALK84 Series, XB4 Series, XB5 Series, ZB4 Series, ZB5 Series See Page 2
Additional information (if necessary may also be reported on page 2)	<input checked="" type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60947-1:2007/AMD1:2010, IEC 60947-1:2007/AMD2:2014, IEC 60947-1:2007, IEC 60947-5-1:2016, IEC 60947-5-5:1997/AMD1:2005, IEC 60947-5-5:1997/AMD2:2016, See Page 2
As shown in the Test Report Ref. No. which forms part of this Certificate	4788731990B issued on 2019-04-16

This CB Test Certificate is issued by the National Certification Body



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2019-05-28

Signature:

Jan-Erik Storgaard



Ref. Certif. No.

DK-83997-UL

Model Details:

Harmony range metal and plastic:

XB4 Series,ZB5 Series,ZB4 Series,XB5 Series followed by BS83, BS84, BS86, BS93, BS94, BS96, BT84, BX84, AS83, AS84, AS86, AS93, AS94, AS96, AT84, AT86, AX84 followed by "... " which represents additional suffixes, and fitted with : ZB..Z009 + ZBE, ZEN or ZB2 followed by "... " which represents additional suffixes
XALK178 Series,XALK84 Series followed by "... " which represents additional suffixes, see test report for nomenclature

Factories:

Schneider Electric a. s.
Cizovska 447 397 01 Pisek
Czech Republic

PT. Schneider Electric Manufacturing Batam
Batam Industrial Park, Blk 1, 4 & 208, Mukakuning Batam Riau 29433
Indonesia

Additional Information:

Additionally evaluated to EN 60947-1:2007/A1:2011/A2:2014 and EN 60947-5-1:2017; National Differences specified in the CB Test Report

Additionally Tested According To:
IEC 60947-5-5:1997

Additional information (if necessary)



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2019-05-28

Signature:

Jan-Erik Storgaard