



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2010010305432340

NAME AND ADDRESS OF THE APPLICANT

Schneider Electric (China) Co. Ltd. Shanghai Branch
No. 669, Suide Road, Putuo District, Shanghai, China

NAME AND ADDRESS OF THE MANUFACTURER

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

NAME AND ADDRESS OF THE FACTORY

PT. Schneider Electric Manufacturing Batam (V049531)
JI Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka Kuning Kel.Muka Kuning Kec. Sungai
Beduk – Batam, Indonesia

PRODUCT NAME, MODEL AND SPECIFICATION

Limit Switch

XCKM, ZCKM: Ui:500V;Uimp:6kV;Ith:10A;AC-15:Ue/Ie:240V/3A;DC-13:Ue/Ie:250V/0.27A;IP66

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification
rules of CQC11-462142-2019 .

Valid from: Aug.26,2020

Valid until: Nov.20,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing
certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0379856



产品认证证书

证书编号: CQC2010010305432340

申请人名称及地址

施耐德电气(中国)有限公司上海分公司
上海市普陀区绥德路 669 号

制造商名称及地址

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

生产企业名称及地址

PT. Schneider Electric Manufacturing Batam(V049531)
JI Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka
Kuning Kel.Muka Kuning Kec. Sungai Beduk - Batam, Indonesia

产品名称和系列、规格、型号

限位开关

XCKM, ZCKM: Ui:500V;Uimp:6kV;Ith:10A;AC-15:Ue/Ie:240V/3A;DC-13:Ue/Ie:250V/0.27A;IP66

产品标准和技术要求

GB/T 14048.5-2017

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462142-2019 认证规则的要求, 特发此证。

发证日期: 2020 年 08 月 26 日 有效期至: 2024 年 11 月 20 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

经中国合格评定国家认可委员会认可 CNAS C001-P

主任:

陆楠



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0379856



产品认证证书

附录

第 1 页 共 2 页

证书编号: CQC2010010305432340

纸号: 379856

型号解释:

注: 此附录与证书同时使用时有效。

主任: _____

陆杨



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



产品认证证书

附录

第 2 页 共 2 页

证书编号: CQC2010010305432340

纸 号: 379856

<u>XCK-M</u>	<u>1</u>	<u>05</u>	<u>H29</u>
I	II	III	IV
I	基本型号: XCK-M: 成品, 3 个电缆进线孔, 2 极 ZCK-M: 基座/触头部件, 2 极 ZCK-D: 操作头 ZCK-Y: 操作杆		
II	触头模块: (空白: 对 ZCK-D, ZCK-Y) 对 XCK-M, ZCK-M. 2 极: 1: NO+NC 瞬动 5: NO+NC 慢断		
III	操作头 空白: 对 ZCK-Y 10-普通头活塞型 02-铜滚轮头活塞型 21-热塑滚轮头水平推杆活塞型 15-带操作杆旋转头-热塑滚轮摆杆 06-万向头-猫须型		
IV	进线孔 空白-用于 Type 11 (CM10) European cable gland 的螺孔, ZCK-D 和 ZCK-Y 产品 H29 - ISO M20 螺孔		

注: 此附录与证书同时使用时有效。

主任: _____

陆杨



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>