



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2011010305484297

NAME AND ADDRESS OF THE APPLICANT

Schneider Electric (China) Co. Ltd. Shanghai Branch
No. 669, Suide Road, Putuo District, Shanghai, China

NAME AND ADDRESS OF THE MANUFACTURER

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

NAME AND ADDRESS OF THE FACTORY

PT. Schneider Electric Manufacturing Batam (V049531)
JI Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka Kuning Kel.Muka Kuning Kec. Sungai
Beduk – Batam, Indonesia

PRODUCT NAME, MODEL AND SPECIFICATION

Inductive Proximity Switch
XS7-T,XS8-T: Ui: 60V; Ue:12-48V DC; Ie: 100mA DC, 200mA DC; Utilization Category: DC-12;Sn:10mm,
15mm,20mm; f:100Hz,150Hz,500Hz,1000Hz; IP67

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.10-2016

TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification
rules of CQC11-462142-2019.

Valid from: Aug.25,2020

Valid until: Jun.27,2021

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing
certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-R

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0372795



产品认证证书

证书编号: CQC2011010305484297

申请人名称及地址

施耐德电气(中国)有限公司上海分公司
上海市普陀区绥德路669号

制造商名称及地址

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

生产企业名称及地址

PT. Schneider Electric Manufacturing Batam(V049531)
Jl Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka
Kuning Kel.Muka Kuning Kec. Sungai Beduk - Batam, Indonesia

产品名称和系列、规格、型号

电感式接近开关

XS7-T,XS8-T: Ui: 60V; Ue:12-48V DC; Ie: 100mA DC, 200mA DC; 使用类别: DC-12; Sn:10mm,
15mm,20mm; f:100Hz,150Hz,500Hz,1000Hz; IP67; 型号解释见附件

产品标准和技术要求

GB/T 14048.10-2016

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462142-2019 认证规则的要求, 特发此证。

发证日期: 2020 年 08 月 25 日 有效期至: 2021 年 06 月 27 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

经中国合格评定国家认可委员会认可 CNAS C001-P

主任:

陆楠



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0372795



产品认证证书

附录

第 1 页 共 1 页

证书编号: CQC2011010305484297

纸号: 372795

型号解释:

Nomenclature of XS7-T, XS8-T							
XS	7-	T	2	D	A	210	LD
I	II	III	IV	V	VI	VII	VIII
I -	产品基本型号 XS - 电感式接近开关						
II -	安装方式 7 - 埋入式 8 - 非埋入式						
III -	外形 T - 立方体, 多方向检测						
IV -	尺寸 2 - 26*26*26mm 4 - 40*40*40mm						
V -	输出接线形式 D - DC 2 线 N - DC 3/4 线 输出 NPN P - DC 3/4 线 输出 PNP						
VI -	输出功能 A - NO (常开) C - NO (常开) + NC (常闭)						
VII -	其他功能 210 - DC 2 线 214 - DC 2 线 (带 4 pin 连接器) 440 - DC 4 线						
VIII -	电缆及电缆接口 Examples below: L1 - 5m 电缆 L2 - 10m 电缆 LD - 0.8m 电缆带浇铸连接器适用于环形栓带 M12 螺纹的锁扣装置 LD01 - 0.15m 电缆带浇铸连接器适用于环形栓带 M12 螺纹的锁扣装置 空白 - 2m 电缆						

注: 此附录与证书同时使用时有效。

主任:

陆梅

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

