



# Certificate of Compliance

Certificate Number: LR 44087-76

Revision: LR 44087-85

Date Issued: March 29, 1995

Issued To: **TÉLÉMÉCANIQUE S.A.**  
33 bis, Avenue du Maréchal Joffre  
92002 Nanterre  
Cédex, France

**SUBMITTOR**

*The products listed below are eligible to bear the CSA Mark.*

Issued By: J.-P. Boivin, Eng.  
Montreal, PQ, CANADA

Signature

## PRODUCTS

CLASS 3211 03 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices

Pushbutton Stations, Type 4,4X and 12, Type XAL-B and XAL-3 with contact units, Types XEN-L or ZB2-BE, 600V ac, HD and/or rating codes A600, Q600 and/or 5A, 600V ac, with pilot lights Types XAL-V6 lamp Ba9S, 130V max, XAL-V7 with resistor 230V max or with transformer, Type XAL-T, 600V/6V, 1.5W max or with illuminated contact units, Types XAL-W6 contacts, 300V ac HD for same polarity, lamp Ba9S, 130V max or XAL-W7 with series resistor, 230V max.

Enclosures for industrial control panels Types XAP.M, metal; XAP-G, metal; XAP.A, insulating material, Type 4,4X and 12.

## APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No.	14-M91	- Industrial Control Equipment
CAN/CSA-C22.2 No.	94-M91	- Special Purpose Enclosures