

CN49024-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Trademark (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

AC contactor

Schneider Shanghai Industrial Control Co., Ltd.

No.629 Suide Road, Putuo District, Shanghai, P.R.China

Schneider Electric a. s.

Cizovska 447 - 39701 Pisek - Czech Republic

Schneider Electric a. s.

Cizovska 447 - 39701 Pisek - Czech Republic

See the Appendix

Schneider Electric

LC1F500,LC1F5004;

Original CB No. is CN49024, dated 2019-12-04. The M1 certificate has been issued to add KUE coil products.

IEC 60947-4-1:2018

00901-CB2019CQC-090423-M1

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China Tel: +86-10-83886666 Fax: +86-10-83886282

website: http://www.cqc.com.cn

Date: Apr.02,2020

市场





CN49024-M1

LC1F500, LC1F5004

Ui:1000V (except for LA4EM module: 380V);

Uimp:8kV (except for LA4EM module: 6kV);

LC1F500:

AC-3: Ue/Ie: 230V/446.5A, 400V/430A, 415V/463.5A, 440V/500A, 500V/488A,

690V/333.3A;

AC-1: Ue/Ie: 230V/400V/415V/440V/500V/690V/1000V/700A;

Ith: 700A;

3P;

LC1F5004:

AC-1: Ue/Ie: 230V/400V/415V/440V/500V/690V/1000V/700A;

Ith: 700A;

4P:

Us: AC48 V/110 V/ 115 V/120 V/208 V/220 V/230 V/240 V/380 V/400 V/415 V/440V,

40...400Hz;

DC24V/48 V/72V/108V/110 V/125 V/220 V/250 V/440 V;

AC100-250V 50-60Hz / DC100-380V (LC1F500KUE / LC1F5004KUE)

Page 1 of 1

Additional information (if necessary)

Date:

Apr.02,2020

市场

Signature: -

Lu Me