



Ref. Certif. No.

HU-001320

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE

CERTIFICAT D'ESSAI OC

Product
Produit

AC Contactors

Name and address of the applicant
Nom et adresse du demandeur

Schneider Electric Industries SAS
35, rue Joseph Monier, 92500 Rueil Malmaison
France

Name and address of the manufacturer
Nom et adresse du fabricant

Schneider Electric a.s.
Cizovska 447 - 39701 Pisek
Czech Republic

Name and address of the factory
Nom et adresse de l'usine

Schneider Electric a.s.
Cizovska 447 - 39701 Pisek
Czech Republic

Note: When more than one factory, please report on page 2
Note: Lorsque il y plus d'une usine, veuillez utiliser la 2^{ème} page

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

Main circuit: Ith= 125A; Ui= 1000V; Uimp= 8kV
Auxiliary circuit: Ith= 10A, Ui= 660V, Uimp= 6kV,
AC-15: 120V/6A, 660V/1,09A,
DC-13: 125V/1,1A, 600V/0,2A
(see page 2 of this Certificate and Test Report for other ratings)

Trademark (if any)
Marque de fabrique (si elle existe)

Schneider Electric

Type of Manufacturer's Testing Laboratories used
Type de programme du laboratoire d'essais constructeur

Model / Type Ref.
Ref. De type

LC1... series, LC2... series, LP1... series
(for details see page 2 of this Certificate)

Additional information (if necessary may also be reported on page 2)
Les informations complémentaires (si nécessaire, peuvent être indiqués sur la 2^{ème} page

A sample of the product was tested and found to be in conformity with
Un échantillon de ce produit a été essayé et a été considéré conforme à la

IEC 60947-4-1:2009 (ed.3)+A1
IEC 60947-5-1:2003 (ed.3)+A1
IEC 60947-1:2007 (ed.5)+A1

As shown in the Test Report Ref. No. Which forms part of this Certificate
Comme indiqué dans le Rapport d'essais numéro de référence qui constitue partie de ce Certificat

28220829 001

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme National de Certification



TÜV Rheinland InterCert Kft., Division MEEI
H-1132 Budapest, Váci út 48/A-B
www.tuv.hu



Date: 2014-06-16

Signature:

Gabor Kassai

Type explanation:

LC1 D80 6 M7

I. II. III. IV.

Possible values:

- I. Basic product type:
 - LC1 – AC or DC coil single contactor (1)
 - LC2 – AC coil reversing contactor (2)
 - LP1 – DC coil single 4 poles contactor (3)
- II. Size:
 - D80 (3 poles)
 - D95 (3 poles)
 - D80004 (4 poles)
 - D80008 (4 poles, 2NO+2NC)
- III. Type of connection:
 - Blank – screw connection
 - 6 – Ring lug connection
- IV. Coil codes: see CB test report

Notes:

- (1) : LC1 "DC coil" only for 3 poles contactors
- (2) : not available for "D80004" and "D80008" versions
- (3) : i.e. only for "D80004" and "D80008" versions

Main circuit ratings:

Reference	Ith	Ue Ie Utilization category	230V	400V	440V	500V	690V
LC1D80 LC2D80 LC1D80004 LP1D80004	125A	Ie (AC-1)	125A				
		Ie (AC-3)	72A	66A	80A	78A	47A
		Ie (AC-4)	60A	55A	66,7A	65A	39,2A
LC1D80008 LP1D80008	125A	Ie (AC-1)	125A				
LC1D95 LC2D95	125A	Ie (AC-1)	125A				
		Ie (AC-3)	81A	80A	95A	78A	47A
		Ie (AC-4)	67,5A	66,7A	79,2A	65A	39,2A

Additional information (if necessary)
Information complémentaire (si nécessaire)



Date: 2014-06-16

TÜV Rheinland InterCert Kft., Division MEEI
H-1132 Budapest, Váci út 48/A-B
www.tuv.hu

Signature:

Gabor Kassai
Gabor Kassai

