






CLOSING PLATES SUPPLIED FACTORY INSTALLED. REMOVE PRIOR TO CONNECTING BRANCH UNIT AND REINSTALL AT END OF LINE UP.

HORIZONTAL CROSS BUS SYSTEM INCLUDES EXCLUSIVE VISI-TITE JOINT-NUTS TO MAKE ALL PHASE AND NEUTRAL CONNECTIONS BETWEEN TWO EZM UNITS.


BONDING STRAP SUPPLIED (FIELD INSTALL WHEN USED AS SERVICE EQUIPMENT)



DUAL DIMENSIONS: INCHES MILLIMETERS

ALTERNATE LUG QUANTITY PER LINE SIDE PHASE AND NEUTRAL TERMINALS (ORDER SEPARATELY)			
CATALOG NUMBER	ANDERSON		ILSCO
	VHCL-600-12BN	VHCL-750-12BN	2ACL-600
	250-600 CU	500-750 CU	250-600 AL/CU
EZM11600GCBC	VC-6 ‡	VC-7 ‡	IDT-12
EZM11600JCBC	6	6	6

‡ INDICATED VERSA-CRIMP CRIMPING TOOL.



NO KNOCKOUTS PROVIDED

SYSTEM TYPE	MAIN RATING (AMPERES)	CATALOG NUMBER	MAIN CIRCUIT BREAKER (FACTORY INSTALLED)	LINE SIDE PHASE LUG WIRE RANGE FOR AL OR CU CONDUCTORS (SUPPLIED WITH BREAKER)	LINE SIDE NEUTRAL LUG WIRE RANGE FOR AL OR CU CONDUCTORS (FACTORY INSTALLED)	GROUND LUG WIRE RANGE (FACTORY INSTALLED)
1Ø 3W 120/240 VAC	1600 ●	EZM11600GCBC EZM11600JCBC	RGF36160U31A RJF36160U31A	(6) 1/0-750 OR (12) 1/0-250	(6) 1/0-750 OR (12) 1/0-250	(1) #6-300

● 1600A MAIN CIRCUIT BREAKER DEVICE MUST BE CENTER MOUNTED.

NOTES:  
FINISH - GRAY BAKED ENAMEL POWDER COAT PAINT OVER CLEANED GALVANNEALED STEEL.  
UL LISTED - FILE E131840, VOL. M  
SUITABLE FOR USE AS SERVICE EQUIPMENT.  
MAIN HORIZONTAL CROSS BUS RATED AT 1200 AMPERES.  
MAIN DEVICES ARE SEALABLE BY UTILITY.  
GANGABLE MULTI-METERING EQUIPMENT IS DESIGNED FOR WALL MOUNTING ONLY.  
(NOT SUITABLE FOR FLOOR STANDING EQUIPMENT.)

<p>EZ METER-PAK GANGABLE MULTI-METERING EQUIPMENT 1600A, 1PH 3W MAIN CIRCUIT BREAKER DEVICE OVERHEAD/UNDERGROUND FEED RAINPROOF NEMA TYPE 3R ENCLOSURE</p>	<p>by Schneider Electric</p>
<p>DWG# PWFDS-SYRS-0005 NO.</p>	