


ERMS MODULE FACTORY INSTALLED





MICROLOGIC P TRIP UNIT WITH THE BLUE ERMS LABEL




ADDITIONAL NOTES:

◆ ALTERNATE LUG KITS ARE AVAILABLE FOR USE ON LINE SIDE OF MOLDED CASE CIRCUIT BREAKER (REFER TO DIGEST 175, PAGE 7-39).



▼ ALTERNATE NEUTRAL LUG AVAILABLE, ORDER ONE (1)KIT, MMLK250 FOR (1) #1/0 AWG-600 KCML OR (2) #1/0 AWG-250 KCML AL/CU (KIT INCLUDES THREE, 2-BARREL LUGS), NEUTRAL WILL ACCOMMODATE TWO, 2-BARREL LUGS ONLY.



TOP MOUNTING BRACKET



BOTTOM MOUNTING BRACKET



SEAL BRACKET

DUAL DIMENSIONS: INCHES MILLIMETERS

SYSTEM TYPE	MAIN RATING (AMPERES)	CATALOG NUMBER	MAIN CIRCUIT BREAKER (FACTORY INSTALLED)	LINE SIDE NEUTRAL LUG WIRE RANGE FOR AL OR CU CONDUCTORS (SUPPLIED WITH BREAKER)	LINE SIDE NEUTRAL LUG WIRE RANGE FOR AL OR CU CONDUCTORS (FACTORY INSTALLED)	GROUND LUG WIRE RANGE (FACTORY INSTALLED)
1Ø3W 120/240VAC	1200	EZM11200GCBTMS	PGF36120U63AE1	(4) 3/0-500◆	(4) 3/0-500▼	(1) #6-300
		EZM11200JCBTMS	PJF36120U63AE1			

NOTES:
 FINISH - GRAY BAKED ENAMEL POWDER COAT PAINT OVER CLEANED GALVANNEALED STEEL.
 UL LISTED - FILE E131840, VOL. M
 SUITABLE FOR USE AS SERVICE EQUIPMENT.
 MAIN HORIZONTAL CROSS BUS RATED AT 1200 AMPERES.
 MAIN DEVICES ARE SEALABLE BY UTILITY.
 GANGABLE MULTI-METERING EQUIPMENT IS DESIGNED FOR WALL MOUNTING ONLY. (NOT SUITABLE FOR FLOOR STANDING EQUIPMENT.)
 *1200A MAIN CIRCUIT BREAKER MUST BE CENTER MOUNTED WHEN USED WITH BRANCH DEVICES WITH MAIN BUS RATED 800A.
 NO USER CONFIGURATION REQUIRED FOR ERMS FUNCTION.
 ERMS SWITCH PROVIDED WITH LOCKABLE COVER.
 ERMS MODULE WIRING DIAGRAM AND REPLACEMENT PARTS PROVIDED ON ENCLOSURE DOOR.

EZ METER-PAK GANGABLE
 MULTI-METERING EQUIPMENT
 1200A 1PH 3W MAIN CIRCUIT BREAKER DEVICES
 TOP FEED
 RAINPROOF NEMA TYPE 3R ENCLOSURES



DWG# PWFDS-SYRS-0108
 NO.