Ref. Certif. No.

CN47511

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Control Relays
Name and address of the applicant	SCHNEIDER ELECTRIC INDUSTRIES SAS 31 Rue Pierre Mendès France, Eybens, 38050 GRENOBLE Cedex 9 - France
Name and address of the manufacturer	SCHNEIDER ELECTRIC INDUSTRIES SAS 31 Rue Pierre Mendès France, Eybens, 38050 GRENOBLE Cedex 9 - France
Name and address of the factory Note: *When more than one factory, please report on page 2*	Schneider Electric Industries S. A. ZAC Le Village Le Vaudreuil - 27100 - France ☑ Additional information on page 2
Ratings and principal characteristics	See the Appendix
Trademark (if any)	Schneider Electric
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	CAD32, CAD50, CAD32…S207, CAD50…S207, CAD32…S335, CAD50…S335
Additional information (if necessary may also be reported on page 2)	
A sample of the product was tested and found to be in conformity with	IEC 60947-5-1:2016(4th Edition)
As shown in the Test Report Ref. No. which forms part of this Certificate	00901-CB2018CQC-082581

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE
Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: http://www.cqc.com.cn

Date: Aug.09,2019

Signature: Lu Mei

CB 0053635

Ref. Certif. No.
CN47511

Name of the factory	Address of the factory
1.PT. Schneider Electric Manufacturing Batam	Jl Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka Kuning Kel.Muka Kuning Kec. Sungai Beduk – Batam, Indonesia

Additional information (if necessary)

Date: Aug.09,2019

Signature: Lu Mei

CHINA QUALITY CERTIFICATION CENTRE
Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666
Fax: +86-10-83886282
website
http://www.cqc.com.cn

CAD32, CAD50, CAD32…S207, CAD50…S207, CAD32…S335, CAD50…S335

Ui:690V;

Uimp:6kV;

Ith:10A;

AC-15:Ue/Ie:120V/6A, 690V/1.04A;

DC-13:Ue/Ie:125V/1.1A, 600V/0.2A;

CAD32, CAD50:

Us:

AC12V/21V/24V/32V/36V/42V/48V/60V/100V/110V/115V/120V/127V/140V/200V/208V/220V/230V/240V/277V/380V/400/415V/440V /480V/500V/575V/600V/660V/690V, 50/60Hz;

DC5V/12V/20V/24V/32V/36V/48V/60V/72V/96V/100V/110V/125V/155V/174V/200V/220V/250V/305V/348V/440V/543V/575V/600V;

DC(Low Consumption):5V/12V/20V/24V/36V/48V/60V/72V/96V/110V/220V/250V;

CAD32…S207, CAD50…S207:Us: DV24V/72V/110V;

CAD32…S335, CAD50…S335:Us: AC24V/230V, 50/60Hz;

IP20,except ring lug connection versions IP10

Additional information (if necessary)

Date: Aug.09,2019

Signature: Lu Mei

CHINA QUALITY CERTIFICATION CENTRE
Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666
Fax: +86-10-83886282
website
http://www.cqc.com.cn