



#### SEISMIC QUANTIFICATION

TO BE COMPLIANT WITH THE SEISMIC REQUIREMENTS OF ASCE/SEI 7, THIS UNIT IS SELF CERTIFIED TO ICS ES AC156, BY SHAKE TABLE QUALIFICATION TESTING. THE ENCLOSURE ABOVE IS 22M.

#### TRANSFORMER SPECIFICATION

150 KVA 3 PHASE 60 HERTZ  
 PRIMARY VOLTAGE: 208/240 DELTA  
 (SHIPPED CONNECTED TO 240 DELTA)  
 SECONDARY VOLTAGE: 480Y/277  
 150°C RISE ABOVE 40°C AMBIENT  
 220°C INSULATION SYSTEM ALUMINUM WINDING  
 APPROXIMATE WEIGHT: 1020 LBS  
 GUARANTEED SOUND LEVEL: 45 dB  
 TYPE 2 ENCLOSURE PAINTED ANSI 49 GREY  
 MINIMUM EFFICIENCY 98.74% @ 35% LOADING 75°C  
 COMPLYING WITH DOE 2016-10 CFR 431  
 (78 FR 23335-APRIL 18, 2013)

#### NOTES:

cULus List TO UL 1561 AND C22.2No47, FILE NUMBER E6868  
 ALL UNITS 100% TESTED PRIOR TO SHIPPING TO NEMA ST-20 (2014)  
 MANUFACTURE IN ISO 9001 FACILITIES  
 GREEN PREMIUM (RoHS/REACH COMPLIANT, PRODUCT ENVIRONMENT PROFILE)  
 REGISTERED TO DOE VIA 10 CFR 429 & NRCAN  
 MINIMUM CLEARANCE 1/2 INCH PER ALCOVE TESTING UL 1561. SIDES AND REAR  
 FRONT ACCESS MUST COMPLY WITH NEC WORK SPACE REQUIREMENTS,  
 MINIMUM CLEARANCE OF 6 INCHES.  
 CONDUIT ENTRY AREA ARE SHOWN ABOVE, LOCATIONS ARE FRONT SIDES  
 AND FRONT BOTTOM

DUAL DIMENSIONS: INCHES  
 MILLIMETERS

LOW VOLTAGE DISTRIBUTION TRANSFORMER  
 DOE 2016  
 DRY TYPE TRANSFORMERS CATALOG NO EXN150T3155H  
 3 PHASE, 208/240 DELTA  
 SECONDARY 480Y/277, ALUMINUM

**SQUARE D**  
 by Schneider Electric

DWG# EXN150T3155H PG 1