



TERMINAL LUGS			
AMPERES	MAX. WIRE	MIN. WIRE	TYPE
1200	(4) 750 KCMIL	(4) #3/0 AWG	75°C AL OR CU

FUSE PROVISIONS			
AMPERES	TYPE	AMPERES	TYPE
1200	CLASS "L"	800	CLASS "L"

\* SIDE ENTRY/EXIT MUST MEET ALL APPLICATION STANDARDS AND CODES.

DUAL DIMENSIONS: INCHES  
MILLIMETERS

CATALOG NUMBER	VOLTAGE RATINGS	WIRING DIAG.	DC HORSEPOWER RATINGS	
			250VDC	600VDC
H228AWK	240VAC; 250VDC	A	50	-
H228NAWK	240VAC; 250VDC	B	50	-
H268AWK	600VAC; 600VDC	A	50	50
HU268AWK	600VAC; 600VDC	C	50	50

NOTES: FINISH - GRAY BAKED ENAMEL-ANSI #49  
ALL NEUTRALS - INSULATED GROUNDABLE (SHIPPED CARTONED FOR FIELD INSTALLATION)  
UL LISTED - FILE E-154828  
CSA CERTIFIED - FILE LL-97406-3  
SUITABLE FOR USE AS SERVICE EQUIPMENT UNLESS A 600/347V OR 480/277V, 1000A OR GREATER, SOLIDLY GROUNDED WYE SYSTEM REQUIRING GROUND FAULT PROTECTION IS USED.  
SHORT CIRCUIT RATING:  
200,000 AMPERES WHEN USED WITH OR PROTECTED BY CLASS L FUSES.  
75 LBS. MAX. FORCE REQUIRED TO OPERATE HANDLE.  
FOR NEMA TYPE 3R APPLICATIONS 1/4-20 DRAIN SCREW MUST BE REMOVED FROM BOTTOM ENDWALL.

HEAVY DUTY SAFETY SWITCHES  
VISIBLE BLADE TYPE  
1200 AMPERE  
ENCLOSURE - NEMA TYPE 12  
NEMA TYPE 3R RAINPROOF  
NEMA TYPE 5 DUST TIGHT (INDOOR)

**SQUARE D COMPANY**

DWG. NO. 1939