



# Certificate of Compliance

**Certificate:** 2181769 (LR 44087-114)

**Master Contract:** 240515

**Project:** 2304489

**Date Issued:** 2010/05/04

**Issued to:** Telemecanique/Schneider Electric

Industries SAS  
Zone Industrielle No. 3  
L'Isle d'Espagnac, 16340  
France  
Attention: Mr. Christophe Delaitre

*The products listed below are eligible to bear the CSA Mark shown*



*J.-C. Chow*

**Issued by:** J.-C. Chow

## **PRODUCTS**

**CLASS 3211 03** - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices

Electronic pressure sensors, Cat. No. XML-E, followed by suffixes, rated 11-33 V dc Class 2 input only, analogue output 4-20 mA, solid state output 100 mA, operating range up to 600 bar; Cat. No. XML-K, followed by suffixes, rated 12/24 or 24 V dc and 5 V dc (for ratiometric option) Class 2 input only, analogue output 4-20mA or 0-10 V or 0-5 V or 1-6 V, ratiometric output 0.5 .. 4.5 V dc (option), operating range up to 25 bar.

## **APPLICABLE REQUIREMENTS**

CAN/CSA-C22.2 No.14-05 - Industrial Control Equipment