

CERTIFICATE OF COMPLIANCE

Certificate Number 20161101 – E22182
Report Reference E22182 - 20020613
Issue Date 2016-NOVEMBER-01

Issued to: SCHNEIDER ELECTRIC USA, INC.
1010 Airpark Center Dr
Nashville, TN 37217 USA

**This is to certify that
representative samples of**

Busways and Associated Fittings
CNL, USL - Power Bus C 100, 225, and 400 A busway and
fittings.

Rated: 100A, 225A, and 400A, 600 V maximum,
Max Short Circuit 35 kA sym.


Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 857, "Busways."
CAN/CSA-C22.2 No. 27 (2000), "Busways."

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

