



# Certificate of Compliance

**Certificate:** 1509070 (LR 29971-28)

**Master Contract:** 153555

**Project:** 2279539

**Date Issued:** 2010/03/02

**Issued to:** Schneider Electric USA, Inc.

Square D  
3700 6th St SW  
Cedar Rapids, IA 52404  
USA  
Attention: Jan Harper

*The products listed below are eligible to bear the CSA Mark shown*



*R. Tateishi, P. Eng.*

Issued by: R. Tateishi, P. Eng.

## PRODUCTS

**CLASS 1451 01** - GROUND FAULT DEVICES - Circuit Interrupters

Combined circuit breaker and ground fault interrupter, 30mA sensitivity, Type QO-EPD and QOB-EPD, Series 2, 1-pole, 15-30A, 120V ac and 2-pole, 15-60A, 120/240V ac.

## APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures

CAN/CSA-C22.2 No. 144 - Ground Fault Circuit Interrupters