

CERTIFICATE OF COMPLIANCE

Certificate Number 20130201-E61542
Report Reference E61542-20020812
Issue Date 2013-FEBRUARY-01

Issued to: DURHAM CO
722 DURHAM RD
PO BOX 908
LEBANON MO 65536


This is to certify that representative samples of METER SOCKETS
See Addendum Page.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL414 Meter Sockets
CSA C22.2 No. 115-M1989 Meter Mounting Devices.

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20130201-E61542
Report Reference E61542-20020812
Issue Date 2013-FEBRUARY-01

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USL, CNL - Cat. No. – U; f/b Prefix Designators; f/b ST; f/b optional suffix designator numbers and letters. Meter socket enclosures incorporate the meter socket base assembly and a test switch and are rated, 30 A continuous, 600 V maximum. See III 1 for Catalog number logic

USL only - Cat. No. – U; f/b Prefix Designators; f/b LT; f/b optional suffix designator numbers and letters. Meter socket enclosures incorporate a lever-bypass type meter socket base assembly and a test switch and are rated, 30 A continuous, 600 V maximum. See III 1 for Catalog number logic..



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

