

Northbrook, Illinois • (847) 272-8800
Melville, New York • (631) 271-6200
Santa Clara, California • (408) 985-2400
Research Triangle Park,
North Carolina • (919) 549-1400
Camas, Washington • (360) 817-5500



CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 101000-E2875D

ISSUE DATE: October 10, 2000

Page 1 of 3

Issued to: Square D Company
1601 Mercer Road
Lexington, KY. 40511 USA

Report Reference: E2875, February 9, 1972


This is to Certify that
representative samples of: Enclosed switches, types D121, D221, D321, DU221, DU321, DU222 &
DU322, suitable for use as service equipment. catalog numbers may have
suffix letters.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s)
indicated on this Certificate.


Standard(s) for Safety: UL 98, Enclosed Switches

Additional Information: See Addendum

Only those products bearing the UL Listing Mark should be considered as being covered by
UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control
number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate
UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer: 
Tom Skibbs
Underwriters Laboratories Inc.

Review Engineer: 
Jake Killinger
Underwriters Laboratories Inc.

A not-for-profit organization
dedicated to public safety and
committed to quality service



CERTIFICATE OF COMPLIANCE - ADDENDUM

CERTIFICATE NUMBER: 101000-E2875D
ISSUE DATE: October 10, 2000

Page 2 of 3

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.


RATINGS


Current - 30 A and 60 A
Voltage - 240 V ac maximum

Short Circuit

When used with Class R fuses with Kit No. DRK-30 properly installed, fusible switches are suitable for use on circuits capable of delivering not more than 100,000 rms symmetrical amperes.

Unfused switches are suitable for use on circuits delivering not more than 100,000 rms symmetrical amperes for 30 A switches, and 50,000 for 60 A switches, when protected by fuses (circuit breaker) rated not more than the switch.

Engineer: 
Tom Skibbs
Underwriters Laboratories Inc.

Review Engineer: 
Jake Killinger
Underwriters Laboratories Inc.




CERTIFICATE OF COMPLIANCE - ADDENDUM


CERTIFICATE NUMBER: 101000-E2875D
ISSUE DATE: October 10, 2000

Page 3 of 3

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

	Amps	Volts(max)	Horsepower (+ indicates maximum rating)		
			Current Voltage	Alternating	Direct
			120	240	125
			Phase	1	3
			Wires	2	2
D121-N	30	120ac/125dc		1.5, 2+	2, 3+
D221	30	240ac		1.5, 3+	
D221-N	30	240ac		1.5, 3+	3, 7.5+
D321	30	240ac		1.5, 3+	3, 7.5+
D321-N	30	240ac			3, 7.5+
DU221	30	240ac		3	
DU321	30	240ac		3	7.5
DU322	30	240ac		10	15
DU222	30	240ac		10	

Engineer: 
 Tom Skibbs
 Underwriters Laboratories Inc.

Review Engineer: 
 Jake Killinger
 Underwriters Laboratories Inc.