

Certificate



Certificate no.

CU 72162714 01

License Holder:

APC by Schneider Electric
800 Federal Street
Andover MA 01810-1067
USA

Manufacturing Plant:

American Power Conversion Corp.
Blk 16, Phase IV, Lot 10, PEZA
4106 Rosario, Cavite
Philippines

Test report no.: USA-DB 30981474 008

Client Reference: Kin Keat

Tested to: UL 1778:2005 R7.06
C22.2 No. 107.3-05 + A1:06

Certified Product: Uninterruptible Power Supply (UPS)

License Fee - Units

Model Designation:

7

- 1) SMX2000RMLV2U, 2) SMX2200RMLV2U, 3) SMX3000RMLV2U,
4) SMX3000RMLV2UNC, 5) SMX2000LV, 6) SMX2000LVNC,
7) SMX3000LV, 8) SMX3000LVNC, 9) SMX3000HVT

Rated Voltage: 1-8) a) AC 100V, 50/60Hz; b) AC 110V, 50/60Hz;
c) AC 120V, 50/60Hz; d) AC 127V, 50/60Hz;
9) AC 208V, 50/60Hz

Rated Current: 1), 5), 6), 9) 16A;
2), 3), 4), 7), 8) 24A


contd.

Special Remarks: Replaces Certificate CU72122864.

Appendix: 1, 1-12

7

Licensed Test mark:



Date of Issue
(day/mo/yr)

31/10/2016

Certificate



Certificate no.

CU 72162714 02

License Holder:

APC by Schneider Electric
800 Federal Street
Andover MA 01810-1067
USA

Manufacturing Plant:

American Power Conversion Corp.
(A.P.C) B.V.
Blk 14, Phase III, Lot 3
4106 Rosario, Cavite PEZA
Philippines

Test report no.: USA-DB 30981474 008

Client Reference: Kin Keat

Tested to: UL 1778:2005 R7.06
C22.2 No. 107.3-05 + A1:06

Certified Product: Uninterruptible Power Supply (UPS)

License Fee - Units

contd.

Protection Class: I


Output Ratings:

- 1), 5), 6) a) 1600W/1600VA; b) 1760W/1760VA;
c) 1800W/1920VA; d) 1800W/2000VA;
2) a) 1980W/2200VA; b) 1980W/2200VA;
c) 1980W/2200VA; d) 1980W/2200VA;
3), 4), 7), 8) a) 2400W/2400VA; b) 2640W/2640VA;
c) 2700W/2880VA; d) 2700W/3000VA;
9) 2700W/3000VA

Additional Manufacturing Plant: see above

(K754170)

Licensed Test mark:



Date of Issue

(day/mo/yr)

31/10/2016

Date : 2016/11/01

APC by Schneider Electric
800 Federal Street
Andover MA 01810-1067
USA

Attn: Kin Keat

Re. : CU US + Canada Certificate

Type of Equipment : Uninterruptible Power Supply (UPS)
Model Designation : See Certificate
Certificate No. : CU 72162714 0001
File No. : 30981474 008
Engineer/Contact : Ditas Benipayo
Standard(s) : UL 1778:2005 R7.06
C22.2 No. 107.3-05 + A1:06

Dear Mr. Keat,

The above referenced technical equipment has been tested and was found to be in compliance with the listed test requirement(s). Enclosed, please find the TUV Rheinland approval document No. CU 72162714 0001. It authorizes you to label the listed product(s) with the TUV Rheinland Mark identified in the approval document. For compliance, the Test Mark must be on the approved unit.

Your product is subject to regular factory follow-up inspections as well as annual certificate and factory registration fees.

In using the TUV Rheinland Mark you are obligated to comply with the TUV Rheinland of North America Service Agreement.

If we can be of any further assistance to you, please do not hesitate to contact us.

Sincerely yours,
Certification Body


Dipl.-Ing. M. Glagla
QA Certification Officer

Enclosure

TUV Rheinland
of North America, Inc.
North American Headquarters

12 Commerce Road
Newtown, CT 06470

Tel 203-426-0888
Fax 203-426-4009
Toll Free TUV-RHEINLAND
Mail info@tuv.com
Web www.tuv.com

Member of
TUV Rheinland Group