



CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 101000 E2875A

ISSUE DATE: October 10, 2000

Page 1 of 2

Issued to: Square D Company
1601 Mercer Road
Lexington, KY. 40511 USA

Report Reference: E2875, March 30, 1971


This is to Certify that
representative samples of: Enclosed switches, type H224, H324, H364, H464, HU364, & HU464,
suitable for use as service equipment. Catalog numbers may have suffix
letters

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s)
indicated on this Certificate.

Standard(s) for Safety: UL 98, Enclosed Switches

Additional Information: See Addendum

Only those products bearing the UL Listing Mark should be considered as being covered by
UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control
number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate
UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer: 
Tom Skibbs
Underwriters Laboratories Inc.

Review Engineer: 
Jake Killinger
Underwriters Laboratories Inc.



CERTIFICATE OF COMPLIANCE - ADDENDUM

CERTIFICATE NUMBER: 101000-E2875A
ISSUE DATE: October 10, 2000

Page 2 of 3

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

RATINGS

Current - 200 A maximum

Short Circuit


When used with Class J or R fuses, fusible switches are suitable for use on circuits capable of delivering not more than 200,000 rms symmetrical amperes.


When used with Class H or K fuses, fusible switches are suitable for use on circuits capable of delivering not more than 10,000 rms symmetrical amperes.

Unfused switches are suitable for use on circuits capable of delivering not more than 50,000 rms symmetrical amperes when protected by Class J, T or R fuses.

Unfused switches are suitable for use on circuits capable of delivering not more than 10,000 rms symmetrical amperes when protected by fuses (circuit breaker) rated not more than the rating of the switch.

Horsepower Ratings (see next addendum page)

Engineer: 
Tom Skibbs
Underwriters Laboratories Inc.

Review Engineer: 
Jake Killinger
Underwriters Laboratories Inc.

CERTIFICATE OF COMPLIANCE - ADDENDUM

CERTIFICATE NUMBER:

Page 2 of 3

ISSUE DATE:

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Catalog No.	Horsepower Ratings (+ indicates maximum rating)														
	Current			Alternating									Direct		
	Voltage 120			240			480			600			125	250	600
	Phase	1	2	3	1	2	3	1	2	3	1	2	3	--	--
Wires	2	4	3	2	4	3	2	4	3	2	4	3	2	2	2
H224				15										40	
H224N				15		25, 60+								40	
H324						25, 60+								40	
H364						25, 60+	25, 50+		50, 125+	30, 50+		60, 150+		40	50
H364N				15		25, 60			50, 125+			60, 150+		40	50
H364						25, 60+			50, 125+			60, 150+			40, 50+
H464						30, 50+		50			50			40	50
HU364				15		60	50		125	50		150		40	50
HU364DS						60			125			150		40	40, 50
HU464						50		50			50			40	50

[Signature]
Engineer

[Signature]
Review Engineer