Certificate of Compliance

Certificate Number 20091130 - E48340

Report Reference E48340, 2009 November 12

Issue Date 2009 November 14



Issued to: SQUARE D CO

3700 6TH ST SW

CEDAR RAPIDS, IA 52404 USA

This is to certify that representative samples of

Circuit Breaker and Ground-fault Circuit Interrupters

Model Descriptions: Circuit breaker and ground fault circuit interrupter, Types

QO and QOB, series 1.

Have been investigated by Underwriters Laboratories Inc.® in accordance

with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: The basic standards used to investigate products in this category are ANSI/UL 489,

"Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker

Enclosures," and ANSI/UL 943, "Ground-Fault Circuit-Interrupters."

Additional Information: This product is a three pole Class "A" ground fault interrupter rated 208Y/120

VAC, 15A, 20A, 30A, 40A & 50A.

These circuit breakers maybe accessorized with an Auxiliary Switch, contact type A

or B or an Alarm Switch.

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle: with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

William Carney
Director, North American Certification Programs