

Certificate of Compliance

Certificate Number: LR 60905-8

Revision: LR 60905-160

Date Issued: July 31, 1996

Issued To: Square D Company
Motor Control Division
Raleigh (Knightsdale) Plant
P.O. Box 27446
Raleigh, NC 27611
Attention: Mr. Horace Sue

The products listed below are eligible to bear the CSA Mark.

Issued By: R. Tateishi, P. Eng.
Toronto, ON CANADA

Signature

CLASS 3211 03 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices
PRODUCTS

Class 8501, Type X relays and timers, open type, 12 poles max, contacts rating: 20A, 600V ac A600; P600, P150, and resistive rating only; 150V ac, 150mA, 8W and 30V dc, 60mA. Coils 6 to 600V ac and 6 to 250V dc.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 14-M91-Industrial Control Equipment

Supplement to Certificate of Compliance

Certificate Number: LR 60905-8

Issued To: SQUARE D CO.
Motor Control Div.
Raleigh (Knightdale) Plant
P.O. Box 27446
Raleigh, NC 27611
Attention: Mr. Horace Sue

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Issued By: R. Tateishi, P. Eng.
Toronto, ON CANADA

Signature

Product Certification History

Revision	Date	Description
-160	July 31/96	Alternate material for cartridge housing assembly.
-136	Sep 21/93	Revised contact rating.
-115	Aug 12/92	Alternate material for carrier and spring guide.
-106	May 20/92	Alternate material for cartridge case.
-91	Jan 22/92	Alternate material for cartridge contact carrier.
-90	Nov 14/91	Alternate insulation tape Type 57 on crossover lead in coil.