tgm

# TEST REPORT

## SEMI F47-0706

## Specification for semiconductor processing equipment
## Voltage sag immunity

**Report reference No**.....: TGM-VA EE 35516 EMC

Tested by
(printed name and signature).....: Dipl.-HTL-Ing. W.Baumgartner .....

Approved by
(printed name and signature).....: Ing. Mag. T. Thun .....

Date of issue.....: 20-May-2014

**Testing Laboratory Name**.....: Staatliche Versuchsanstalt – TGM Elektrotechnik und Elektronik

Address.....: A-1200 Wien, Wexstrasse 19-23

Testing Location.....: Staatliche Versuchsanstalt – TGM Elektrotechnik und Elektronik

Address.....: A-1200 Wien, Wexstrasse 19-23

**Applicant's Name** .....: Siemens AG (Österreich)

Address.....: Siemensstraße 92, 1210 Wien, Austria

**Test specification**

Standard.....: SEMI F47-0706

Test procedure.....: According to IEC 61000-4-11 CE-Scheme

Non-standard testmethod.....: N/A

**Test Report Form No**.....: SEMI_F47

Master TRF.....: July2007

**Test item description**.....: Power supply

Trademark.....: SITOP PSU200M, SITOP PSU8200

Manufacturer .....: Siemens AG

Model and/or type reference.....: 6EP1333-3BA10 (5A)
6EP1334-3BA10 (10A)
6EP3333-8SB00-0AY0 (5A)
6EP3334-8SB00-0AY0 (10A)

Serial number.....: Pre sample

Rating(s).....:

| Model: | Input: | Output: |
|---|---|---|
| 6EP1333-3BA10 | 120-230/230-500Vac; 2,2/1,2A; 50/60Hz | 24Vdc; 5A |
| 6EP1334-3BA10 | 120-230/230-500Vac; 4,4/2,4A; 50/60Hz | 24Vdc; 10A |
| 6EP3333-8SB00-0AY0 | 120/230Vac; 2,1/1,2A; 50/60Hz | 24Vdc; 5A |
| 6EP3334-8SB00-0AY0 | 120/230Vac; 4,0/1,9A; 50/60Hz | 24Vdc; 10A |

Copy of marking plate:

6EP1333-3BA10:




6EP1334-3BA10:

6EP3333-8SB00-0AY0:




6EP3334-8SB00-0AY0: