6AV7863-4TB10-0AA0

Data sheet

SIMATIC IFP2200 Flat Panel 22" display (16: 9), Touch, Extended version up to 30 m, 1920x 1080 pixels, for 24 V DC and 100-240 V AC, display port/DVI interface incl. DVI/USB cable 1.8 m



General information	
Product type designation	IFP2200
Short designation	Flat Panel 22" touch ext.
Display	
Design of display	TFT widescreen display, LED backlighting
Screen diagonal	21.5 in; 22"
Screen diagonal [cm]	56 cm
Display width	476 mm
Display height	268 mm
On Screen Display (OSD) configuration	No; Adjustable by means of software
Number of colors	16 777 216; 24 bit
Viewing angle	170° x 170°
Resolution (pixels)	
 Image resolution 	1 920 x 1 080
 Horizontal image resolution 	1 920 pixel
 Vertical image resolution 	1 080 pixel
 Pixel size, horizontal 	0.2475 mm
Pixel size, vertical	0.2475 mm
General features	
 Brightness/contrast 	250 cd/m² / 1 000:1
 Detachable from computer unit 	30 m
Luminance	250 cd/m²
Backlighting	
 Type of backlighting 	LED
 MTBF backlighting (at 25 °C) 	50 000 h; At 25°C
 Backlight dimmable 	Yes; 0-100 %
Control elements	
Control elements	single-touch screen
Input device	
Integrated mouse cursor control	No
Keyboard fonts	
 Function keys 	No
 — Number of function keys 	0
Touch operation	
 Design as touch screen 	Yes; Analog-resistive
 Monitor keyboard 	Yes
Installation type/mounting	

Design	Built-in unit
Front mounting	Yes
Built-in unit	Yes; Portrait mode possible
maximum permitted forward tilt angle from vertical	35°
maximum permitted backward tilt angle from vertical	35°
Supply voltage	
Type of supply voltage	AC/DC
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Rated value (AC)	100 V; Up to 240V, 50/60 Hz
permissible range, lower limit (AC)	90 V
permissible range, upper limit (AC)	264 V
Power loss	
Power loss, typ.	40 W
Power loss, max.	65 W
Interfaces	
USB on the rear	Yes; 2x onboard
Connection for keyboard/mouse	USB
Video interfaces	
analog video signal (VGA)	No
• DVI-D	Yes
DisplayPort	Yes; DisplayPort V1.1
Touch interfaces	, co, Display, oit in
• USB	Yes
Degree and class of protection	
IP (at the front)	IP65
NEMA (front)	
Enclosure Type 4 at the front	Yes
Standards, approvals, certificates	Ves
Standards, approvals, certificates CE mark	Yes Yes: Corresponds to III 508
Standards, approvals, certificates CE mark cULus	Yes; Corresponds to UL 508
Standards, approvals, certificates CE mark cULus RCM (formerly C-TICK)	Yes; Corresponds to UL 508 Yes
Standards, approvals, certificates CE mark cULus RCM (formerly C-TICK) KC approval	Yes; Corresponds to UL 508
Standards, approvals, certificates CE mark cULus RCM (formerly C-TICK) KC approval Use in hazardous areas	Yes; Corresponds to UL 508 Yes Yes
Standards, approvals, certificates CE mark cULus RCM (formerly C-TICK) KC approval Use in hazardous areas • FM Class I Division 2	Yes; Corresponds to UL 508 Yes
Standards, approvals, certificates CE mark cULus RCM (formerly C-TICK) KC approval Use in hazardous areas • FM Class I Division 2 Ambient conditions	Yes; Corresponds to UL 508 Yes Yes
Standards, approvals, certificates CE mark cULus RCM (formerly C-TICK) KC approval Use in hazardous areas • FM Class I Division 2 Ambient conditions Ambient temperature during operation	Yes; Corresponds to UL 508 Yes Yes No
Standards, approvals, certificates CE mark cULus RCM (formerly C-TICK) KC approval Use in hazardous areas • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min.	Yes; Corresponds to UL 508 Yes Yes No 0 °C
Standards, approvals, certificates CE mark cULus RCM (formerly C-TICK) KC approval Use in hazardous areas • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max.	Yes; Corresponds to UL 508 Yes Yes No
Standards, approvals, certificates CE mark cULus RCM (formerly C-TICK) KC approval Use in hazardous areas • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max. Ambient temperature during storage/transportation	Yes; Corresponds to UL 508 Yes Yes No 0 °C 45 °C; Vertical installation (horizontal)
Standards, approvals, certificates CE mark cULus RCM (formerly C-TICK) KC approval Use in hazardous areas • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max. Ambient temperature during storage/transportation • min.	Yes; Corresponds to UL 508 Yes Yes No 0 °C 45 °C; Vertical installation (horizontal)
Standards, approvals, certificates CE mark cULus RCM (formerly C-TICK) KC approval Use in hazardous areas • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max. Ambient temperature during storage/transportation • min. • max.	Yes; Corresponds to UL 508 Yes Yes No 0 °C 45 °C; Vertical installation (horizontal)
Standards, approvals, certificates CE mark cULus RCM (formerly C-TICK) KC approval Use in hazardous areas • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max. Ambient temperature during storage/transportation • min. • max. Relative humidity	Yes; Corresponds to UL 508 Yes Yes No 0 °C 45 °C; Vertical installation (horizontal) -20 °C 60 °C
Standards, approvals, certificates CE mark cULus RCM (formerly C-TICK) KC approval Use in hazardous areas • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max. Ambient temperature during storage/transportation • min. • max.	Yes; Corresponds to UL 508 Yes Yes No 0 °C 45 °C; Vertical installation (horizontal)
Standards, approvals, certificates CE mark cULus RCM (formerly C-TICK) KC approval Use in hazardous areas • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max. Ambient temperature during storage/transportation • min. • max. Relative humidity • Operation, max.	Yes; Corresponds to UL 508 Yes Yes No 0 °C 45 °C; Vertical installation (horizontal) -20 °C 60 °C
Standards, approvals, certificates CE mark cULus RCM (formerly C-TICK) KC approval Use in hazardous areas • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max. Ambient temperature during storage/transportation • min. • max. Relative humidity • Operation, max. Vibrations • Vibration load in operation	Yes; Corresponds to UL 508 Yes Yes No 0 °C 45 °C; Vertical installation (horizontal) -20 °C 60 °C 95 %; no condensation
Standards, approvals, certificates CE mark cULus RCM (formerly C-TICK) KC approval Use in hazardous areas • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max. Ambient temperature during storage/transportation • min. • max. Relative humidity • Operation, max. Vibrations	Yes; Corresponds to UL 508 Yes Yes No 0 °C 45 °C; Vertical installation (horizontal) -20 °C 60 °C 95 %; no condensation
Standards, approvals, certificates CE mark cULus RCM (formerly C-TICK) KC approval Use in hazardous areas • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max. Ambient temperature during storage/transportation • min. • max. Relative humidity • Operation, max. Vibrations • Vibration load in operation • Vibration load during transport/storage	Yes; Corresponds to UL 508 Yes Yes No 0 °C 45 °C; Vertical installation (horizontal) -20 °C 60 °C 95 %; no condensation
Standards, approvals, certificates CE mark cULus RCM (formerly C-TICK) KC approval Use in hazardous areas • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max. Ambient temperature during storage/transportation • min. • max. Relative humidity • Operation, max. Vibrations • Vibration load in operation • Vibration load during transport/storage Shock testing	Yes; Corresponds to UL 508 Yes Yes No 0 °C 45 °C; Vertical installation (horizontal) -20 °C 60 °C 95 %; no condensation
Standards, approvals, certificates CE mark cULus RCM (formerly C-TICK) KC approval Use in hazardous areas • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max. Ambient temperature during storage/transportation • min. • max. Relative humidity • Operation, max. Vibrations • Vibration load in operation • Vibration load during transport/storage Shock testing • Shock load during operation	Yes; Corresponds to UL 508 Yes Yes No 0 °C 45 °C; Vertical installation (horizontal) -20 °C 60 °C 95 %; no condensation 10 m/s² 10 m/s² 150 m/s²
Standards, approvals, certificates CE mark cULus RCM (formerly C-TICK) KC approval Use in hazardous areas • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max. Ambient temperature during storage/transportation • min. • max. Relative humidity • Operation, max. Vibrations • Vibration load in operation • Vibration load during transport/storage Shock testing • Shock load during operation • shock acceleration during storage/transport Mechanics/material	Yes; Corresponds to UL 508 Yes Yes No 0 °C 45 °C; Vertical installation (horizontal) -20 °C 60 °C 95 %; no condensation 10 m/s² 10 m/s² 150 m/s²
Standards, approvals, certificates CE mark cULus RCM (formerly C-TICK) KC approval Use in hazardous areas • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max. Ambient temperature during storage/transportation • min. • max. Relative humidity • Operation, max. Vibrations • Vibration load in operation • Vibration load during transport/storage Shock testing • Shock load during operation • shock acceleration during storage/transport	Yes; Corresponds to UL 508 Yes Yes No 0 °C 45 °C; Vertical installation (horizontal) -20 °C 60 °C 95 %; no condensation 10 m/s² 10 m/s² 150 m/s²
Standards, approvals, certificates CE mark cULus RCM (formerly C-TICK) KC approval Use in hazardous areas • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max. Ambient temperature during storage/transportation • min. • max. Relative humidity • Operation, max. Vibrations • Vibration load in operation • Vibration load during transport/storage Shock testing • Shock load during operation • shock acceleration during storage/transport Mechanics/material Enclosure material (front) • Aluminum	Yes; Corresponds to UL 508 Yes Yes No 0 °C 45 °C; Vertical installation (horizontal) -20 °C 60 °C 95 %; no condensation 10 m/s² 10 m/s² 150 m/s² 150 m/s²
Standards, approvals, certificates CE mark cULus RCM (formerly C-TICK) KC approval Use in hazardous areas • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max. Ambient temperature during storage/transportation • min. • max. Relative humidity • Operation, max. Vibrations • Vibration load in operation • Vibration load during transport/storage Shock testing • Shock load during operation • shock acceleration during storage/transport Mechanics/material Enclosure material (front) • Aluminum Dimensions	Yes; Corresponds to UL 508 Yes Yes No 0 °C 45 °C; Vertical installation (horizontal) -20 °C 60 °C 95 %; no condensation 10 m/s² 10 m/s² 150 m/s² 150 m/s² Yes
Standards, approvals, certificates CE mark cULus RCM (formerly C-TICK) KC approval Use in hazardous areas • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max. Ambient temperature during storage/transportation • min. • max. Relative humidity • Operation, max. Vibrations • Vibration load in operation • Vibration load during transport/storage Shock testing • Shock load during operation • shock acceleration during storage/transport Mechanics/material Enclosure material (front) • Aluminum	Yes; Corresponds to UL 508 Yes Yes No 0 °C 45 °C; Vertical installation (horizontal) -20 °C 60 °C 95 %; no condensation 10 m/s² 10 m/s² 150 m/s² 150 m/s²

Mounting cutout, width	542 mm; Tolerance: +1 mm
Mounting cutout, height	362 mm; Tolerance: +1 mm
Overall depth	62.5 mm
Weights	
Weight without packaging	6.5 kg
Weight incl. packaging	7.6 kg

last modified: 12/16/2020 ☑