6AV2125-2AE03-0AX0

## **Data sheet**



SIMATIC HMI connection box compact for Mobile Panels, installation in control cabinet, PROFINET and PROFIsafe, connection of safety relay, Connection point detection

General information		
Product type designation	Connection box	
Product function		
<ul> <li>Web-based management</li> </ul>	No	
FH technology		
Safety evaluation through direct wiring		
<ul> <li>Reconnection without emergency stop circuit interruption</li> </ul>	No	
<ul> <li>Reconnection with emergency stop circuit interruption</li> </ul>	Yes	
<ul> <li>Monitoring the STOP button</li> </ul>	Yes	
<ul> <li>Monitoring of emergency stop button</li> </ul>	Yes	
Monitoring of acknowledgement button	Yes	
Safety evaluation via PROFIsafe		
<ul> <li>Reconnection without emergency stop circuit interruption</li> </ul>	Yes	
<ul> <li>Reconnection with emergency stop circuit interruption</li> </ul>	No	
<ul> <li>Monitoring the STOP button</li> </ul>	Yes	
<ul> <li>Monitoring of emergency stop button</li> </ul>	Yes	
<ul> <li>Monitoring of acknowledgement button</li> </ul>	Yes	
Installation type/mounting		
Wall mounting/direct mounting	No	
Control cabinet installation	Yes	
Supply voltage		
Type of supply voltage	DC	
Rated value (DC)	24 V	
permissible range, lower limit (DC)	19.2 V	
permissible range, upper limit (DC)	28.8 V	
Input current		
Current consumption (rated value)	18 mA	
Starting current inrush I²t	0.003 A <sup>2</sup> ·s	
Power		
Active power input, typ.	0.43 W	
Interfaces		
Number of industrial Ethernet interfaces	2	
Number of PROFINET interfaces	2	
Connection point identification	Yes	

Industrial Ethernet	
Industrial Ethernet status LED	0
Protocols	
PROFINET	Yes; No switch functionality
IRT	No
PROFIsafe	Yes; No switch functionality
EtherNet/IP	Yes
AS-Interface	No
EIB/KNX	No
Protocols (Ethernet)	
• TCP/IP	Yes; No switch functionality
• DHCP	No
• SNMP	No
• DCP	No
• LLDP	No
Redundancy mode	
Media redundancy	
— MRP	No
Further protocols	
MODBUS	Yes
<ul><li>other bus systems</li></ul>	No
EMC	
Emission of radio interference acc. to EN 55 011	
Limit class A, for use in industrial areas	Yes; EN 61000-6-4, interference emission: Intended for use in industrial
	areas.
Limit class B, for use in residential areas	No
Degree and class of protection	
IP (at the front)	IP65
IP (rear)	IP20
Standards, approvals, certificates	
CE mark	Yes
cULus	Yes
RCM (formerly C-TICK)	Yes
KC approval	No; Available soon
Suitable for safety functions	Yes
Highest safety class achievable in safety mode	
<ul> <li>Performance level according to ISO 13849-1</li> </ul>	PLe
SIL acc. to IEC 61508	SIL 3
Use in hazardous areas	
ATEX Zone 2	No
ATEX Zone 22	No
<ul> <li>cULus Class I Zone 1</li> </ul>	No
<ul> <li>cULus Class I Zone 2, Division 2</li> </ul>	No
FM Class I Division 2	No
Marine approval	
<ul> <li>Germanischer Lloyd (GL)</li> </ul>	Yes
<ul> <li>American Bureau of Shipping (ABS)</li> </ul>	Yes
Bureau Veritas (BV)	No; Available soon
<ul> <li>Det Norske Veritas (DNV)</li> </ul>	Yes
<ul> <li>Korean Register of Shipping (KRS)</li> </ul>	No
<ul> <li>Lloyds Register of Shipping (LRS)</li> </ul>	Yes
<ul> <li>Nippon Kaiji Kyokai (Class NK)</li> </ul>	Yes
<ul> <li>Polski Rejestr Statkow (PRS)</li> </ul>	No
<ul> <li>Chinese Classification Society (CCS)</li> </ul>	No
Ambient conditions	
Ambient temperature during operation	
• min.	0 °C
• max.	55 °C

Relative humidity	
<ul> <li>Operation, max.</li> </ul>	90 %
Configuration	
Configuration software	
<ul> <li>STEP 7 Professional (TIA Portal)</li> </ul>	No
<ul> <li>WinCC Comfort (TIA Portal)</li> </ul>	No
<ul> <li>WinCC Advanced (TIA Portal)</li> </ul>	No
<ul> <li>WinCC Professional (TIA Portal)</li> </ul>	No
Mechanics/material	
Enclosure material (front)	
<ul> <li>Plastic</li> </ul>	Yes
Aluminum	No
Stainless steel	No
Dimensions	
Width of the housing front	96 mm
Height of housing front	125 mm
Depth of housing	78 mm
Mounting cutout, width	77.5 mm
Mounting cutout, height	106.5 mm
Overall depth	30 mm
Weights	
Weight (without packaging)	0.25 kg
Weight (with packaging)	0.29 kg
Other	
Usable in the following products	
Product 1	6AV2125-*
	c1
last modified:	8/6/2021 🗗