SIEMENS

Data sheet

3RU2116-1EB0



Overload relay 2.8...4.0 A Thermal For motor protection Size S00, Class 10 Contactor mounting Main circuit: Screw Auxiliary circuit: Screw Manual-Automatic-Reset

product brand name	SIRIUS
product designation	thermal overload relay
product type designation	3RU2
General technical data	
size of overload relay	S00
size of contactor can be combined company-specific	S00
power loss [W] for rated value of the current at AC in hot operating state	5.7 W
• per pole	1.9 W
insulation voltage with degree of pollution 3 at AC rated value	690 V
surge voltage resistance rated value	6 kV
maximum permissible voltage for safe isolation in networks with grounded star point	
 between auxiliary and auxiliary circuit 	440 V
 between auxiliary and auxiliary circuit 	440 V
 between main and auxiliary circuit 	440 V
 between main and auxiliary circuit 	440 V
shock resistance according to IEC 60068-2-27	8g / 11 ms
type of protection according to ATEX directive 2014/34/EU	Ex II (2) GD
certificate of suitability according to ATEX directive 2014/34/EU	DMT 98 ATEX G 001
reference code according to IEC 81346-2	F
Substance Prohibitance (Date)	10/01/2009
Ambient conditions	
installation altitude at height above sea level maximum	2 000 m
ambient temperature	
 during operation 	-40 +70 °C
 during storage 	-55 +80 °C
 during transport 	-55 +80 °C
temperature compensation	-40 +60 °C
relative humidity during operation	10 95 %
Main circuit	
number of poles for main current circuit	3
adjustable current response value current of the current-dependent overload release	2.8 4 A
operating voltage	
 rated value 	690 V
• at AC-3e rated value maximum	690 V
operating frequency rated value	50 60 Hz

operational ourrant rated value	4 A
operational current rated value operational current at AC-3e at 400 V rated value	4 A 4 A
operating power	4A
• at AC-3	
- at 400 V rated value	1.5 kW
— at 500 V rated value	2.2 kW
— at 690 V rated value	3 kW
• at AC-3e	5 KW
- at 400 V rated value	1.5 kW
— at 500 V rated value	2.2 kW
— at 690 V rated value	3 kW
Auxiliary circuit	J KVV
	integrated
design of the auxiliary switch number of NC contacts for auxiliary contacts	integrated 1
note	for contactor disconnection
number of NO contacts for auxiliary contacts	
note	for message "Tripped"
number of CO contacts for auxiliary contacts	0
operational current of auxiliary contacts at AC-15	
• at 24 V	3 A
• at 24 v • at 110 V	3 A
• at 120 V	3 A
• at 120 V • at 125 V	3 A
• at 230 V	2 A
• at 200 V	1A
operational current of auxiliary contacts at DC-13	
• at 24 V	2 A
• at 24 V	0.3 A
• at 110 V	0.22 A
• at 125 V	0.22 A
• at 220 V	0.11 A
contact rating of auxiliary contacts according to UL	B600 / R300
Protective and monitoring functions	2000 / 1000
trip class	CLASS 10
design of the overload release	thermal
UL/CSA ratings	
full-load current (FLA) for 3-phase AC motor	
at 480 V rated value	4 A
at 600 V rated value	4 A
Short-circuit protection	
design of the fuse link	
 for short-circuit protection of the auxiliary switch 	fuse gG: 6 A, quick: 10 A
required	
Installation/ mounting/ dimensions	
mounting position	any
fastening method	Contactor mounting
height	76 mm
width	45 mm
depth	70 mm
Connections/ Terminals	
product component removable terminal for auxiliary	No
and control circuit	
type of electrical connection	
 for main current circuit 	screw-type terminals
 for auxiliary and control circuit 	screw-type terminals
arrangement of electrical connectors for main current circuit	Top and bottom
type of connectable conductor cross-sections	
 for main contacts 	
 — solid or stranded 	2x (0,5 1,5 mm²), 2x (0,75 2,5 mm²), 2x 4 mm²

-	nded with core end process	-	2x (0.5 1.5 mm²), 2x (0.7			
	for main contacts		2x (20 16), 2x (18 14),	2x 12		
	conductor cross-section	S				
 for auxiliary cor 						
— solid or stranded			2x (0.5 1.5 mm²), 2x (0.75 2.5 mm²)			
— finely stranded with core end processing		-	2x (0.5 1.5 mm ²), 2x (0.75 2.5 mm ²)			
at AWG cables for auxiliary contacts		2	2x (20 16), 2x (18 14)			
tightening torque						
• for main contacts with screw-type terminals).8 1.2 N·m			
for auxiliary contacts with screw-type terminals			0.8 1.2 N·m			
design of screwdriver shaft			Diameter 5 6 mm			
size of the screwdriver tip			Pozidriv PZ 2			
•	d of the connection screw					
 for main contact 			ЛЗ			
-	and control contacts	Ν	ЛЗ			
Safety related data						
failure rate [FIT] with 31920	low demand rate according	to SN 5	50 FIT			
MTTF with high dem	nand rate	2	2 280 y			
_	st interval or service life acco		20 y			
	on the front according to	IEC	P20			
	the front according to IE	C 60529 fi	inger-safe, for vertical cont	act from the front		
Display			inger eare, ier terdear een			
display version for sw	vitching status	S	Slide switch			
Certificates/ approval	-	_				
Certificates/ approval	-					
Certificates/ approval General Product Ap	ls				For use in hazard-	
	ls				For use in hazard- ous locations	
	ls	Confirmation	<u> </u>			
	ls	Confirmation	ጫ	C D T		
	ls	Confirmation	(III)	EAC		
	ls	Confirmation	(UL)	EAC		
	ls	Confirmation	U	EAC		
General Product Ap	ls	Confirmation	UL	EAC		
General Product Ap	ls		UL Test Certificates	EAC		
General Product Ap	ls oproval		UL UL Test Certificates	EAC	ous locations	
General Product Ap	ls oproval			ERC Special Test Certific-	ous locations	
General Product Ap	ls oproval		Test Certificates	ERC Special Test Certific- ate	ous locations	
General Product Ap	ls oproval	^{nity}	Type Test Certific-		ous locations	
General Product Ap	ls oproval		Type Test Certific-		ous locations	
General Product Ap	ls oproval	^{nity}	Type Test Certific-		ous locations	
General Product Ap	ls opproval	^{nity}	Type Test Certific-		ous locations	
General Product Ap	ls opproval	^{nity}	Type Test Certific-		ous locations	
General Product Ap	ls opproval	^{nity}	Type Test Certific-		ous locations	
General Product Ap	ls opproval	^{nity}	Type Test Certific-		ous locations	
General Product Ap	ls opproval	^{nity}	Type Test Certific-		ous locations	
General Product Ap	oproval	nity CEC-Konf.	Type Test Certific-		ous locations	
General Product Ap	ls opproval	^{nity}	Type Test Certific-		ous locations	
General Product Ap General Product Ap CSA For use in hazard- ous locations	oproval	nity CEC-Konf.	Type Test Certific-		ous locations	
General Product Ap General Product Ap Constructions For use in hazard- ous locations For use in hazard- ous locations For use in hazard- ous locations	Declaration of Conform	nity CEC-Konf.	Type Test Certific-		ous locations	
General Product Ap General Product Ap CSA For use in hazard- ous locations	oproval	nity CEC-Konf.	Type Test Certific-		ous locations	
General Product Ap General Product Ap Constant For use in hazard- ous locations For use in hazard- ous locations For use in hazard- ous locations For use in hazard- ous locations For use in hazard- ous locations	Is opproval CCC Declaration of Conform	nity CEC-Konf.	Type Test Certific-		ous locations	
General Product Ap General Product Ap Constructions For use in hazard- ous locations For use in hazard- ous locations For use in hazard- ous locations	Declaration of Conform	nity CEC-Konf.	Type Test Certific-		ous locations	

Further information

Information- and Downloadcenter (Catalogs, Brochures,...)

https://www.siemens.com/ic10

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3RU2116-1EB0

Cax online generator

http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3RU2116-1EB0

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

https://support.industry.siemens.com/cs/ww/en/ps/3RU2116-1EB0


Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...) http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3RU2116-1EB0&lang=en

Characteristic: Tripping characteristics, I²t, Let-through current

https://support.industry.siemens.com/cs/ww/en/ps/3RU2116-1EB0/char

Further characteristics (e.g. electrical endurance, switching frequency)

http://www.automation.siemens.com/bilddb/index.aspx?view=Search&mlfb=3RU2116-1EB0&objecttype=14&gridview=view1



last modified:

3/8/2022 🖸